



MXS-E/F/G/H

Multi Inverter heat pump



HEAT PUMP

Outdoor Units	WALL MOUNTED											FLEXI TYPE				FLOOR STANDING					SLIM CONCEALED CEILING				CONCEALED CEILING				ROUND FLOW CASSETTE			4-WAY BLOW CASSETTE 600X600				CEILING SUSPENDED							
	FTXG-J			FTXS-J								FTX-JV			FLXS-B				FVXS-F			FVXG-K		FDXS-E/C				FDBQ-B/FBQ-C				FCQ-C8			FFQ-B				FHQ-B				
	25	35	50	20	25	35	42	50	60	71	20	25	35	25	35	50	60	25	35	50	25	35	50	25E	35E	50C	60C	25	35	50	60	35	50	60	25	35	50	60	35	50	60		
2MXS40H	•	•		•	•	•				•	•	•	•	•	•		•	•	•	•	•	•	•	•	•																		
2MXS50H	•	•	•	•	•	•	•	•		•	•	•	•	•	•		•	•	•	•	•	•	•	•	•									•	•	•							
3MXS52E	•	•	•	•	•	•	•	•					•	•	•		•	•	•	•	•	•	•	•	•		•	•	•		•	•	•	•	•	•	•	•	•	•	•	•	
3MXS68G	•	•	•	•	•	•	•	•					•	•	•		•	•	•	•	•	•	•	•	•		•	•	•		•	•	•	•	•	•	•	•	•	•	•	•	
4MXS68F	•	•	•	•	•	•	•	•					•	•	•		•	•	•	•	•	•	•	•	•		•	•	•		•	•	•	•	•	•	•	•	•	•	•	•	
4MXS80E	•	•	•	•	•	•	•	•					•	•	•		•	•	•	•	•	•	•	•	•		•	•	•		•	•	•	•	•	•	•	•	•	•	•	•	
5MXS90E	•	•	•	•	•	•	•	•					•	•	•		•	•	•	•	•	•	•	•	•		•	•	•		•	•	•	•	•	•	•	•	•	•	•	•	

1. Following combination is not possible: 25 + 25 + 25 + 25

2. Following combinations are not possible: 20 + 25 + 25 + 35 + 50 / 20 + 25 + 35 + 35 + 35 / 25 + 25 + 35 + 35 + 35



HEAT PUMP

Indoor Units			FTXG25JW / FTXG25JS		FTXG35JW / FTXG35JS			FTXG50JS / FTXG50JW					
Dimensions	(Height x Width x Depth)		mm		295x915x155								
Weight			kg		11.0								
Air Flow Rate	Cooling	H/M/L/SL	m³/min		8.8 / 6.8 / 4.7 / 3.8			10.1 / 7.3 / 4.6 / 3.9			10.5 / 8.7 / 6.9 / 5.9		
	Heating	H/M/L/SL	m³/min		9.6 / 7.9 / 6.2 / 5.4			10.8 / 8.6 / 6.4 / 5.6			11.4 / 9.8 / 8.1 / 7.1		
Sound Power	Cooling	High	dBA		54.0			58.0			64.0		
	Heating	High	dBA		55.0			58.0			64.0		
Sound Pressure	Cooling	H/M/L/SL	dBA		38.0 / 32.0 / 25.0 / 22.0			42.0 / 34.0 / 26.0 / 23.0			47.0 / 41.0 / 35.0 / 32.0		
	Heating	H/M/L/SL	dBA		39.0 / 34.0 / 28.0 / 25.0			42.0 / 36.0 / 29.0 / 26.0			47.0 / 41.0 / 35.0 / 32.0		
Refrigerant			Type		R-410A								
Power Supply					1~/220-240V/50Hz								



HEAT PUMP

Indoor Units			FTXS20J	FTXS25J	FTXS35J	FTXS42J	FTXS50J	FTXS60G	FTXS71G																
Dimensions	(Height x Width x Depth)		mm		295x800x215			290x1050x250																	
Weight			kg		9			10																	
Air Flow Rate	Cooling	H/M/L/SL	m³/min		9.4 / 7.4 / 5.5 / 4.0			9.1 / 7.1 / 5.2 / 3.7			10.4 / 7.7 / 4.8 / 3.5			9.1 / 7.7 / 6.3 / 5.4			10.2 / 8.6 / 7.0 / 6.0			16 / 13.8 / 11.3 / 10.1			17.2 / 14.5 / 11.5 / 10.5		
	Heating	H/M/L/SL	m³/min		9.9 / 8.2 / 6.5 / 5.5			9.8 / 7.9 / 6.2 / 5.2			10.6 / 8.5 / 6.4 / 5.4			11.2 / 9.4 / 7.7 / 6.8			11.0 / 9.3 / 7.6 / 6.7			17.2 / 14.9 / 11.6 / 11.3			19.5 / 16.7 / 14.2 / 12.6		
Sound Power	Cooling	High	dBA		54			54			58			58			59			61			62		
	Heating	High	dBA		56			56			57			58			60			60			62		
Sound Pressure	Cooling	H/L/SL	dBA		38 / 25 / 22			38 / 25 / 22			42 / 26 / 23			42 / 33 / 30			43 / 34 / 31			45 / 41 / 36 / 33			46 / 42 / 37 / 34		
	Heating	H/L/SL	dBA		38 / 28 / 25			39 / 28 / 25			42 / 29 / 26			42 / 33 / 30			44 / 34 / 31			44 / 40 / 35 / 32			46 / 42 / 37 / 34		
Refrigerant			Type		R-410A																				
Power Supply					1~/220-230-240V/50Hz												1~/220-240V/50Hz								



HEAT PUMP						
Indoor Units				FTX20JV	FTX25JV	FTX35JV
Dimensions	(Height x Width x Depth)		mm	283x770x198		
Weight			kg	7		
Air Flow Rate	Cooling	H/M/L/SL	m³/min	9.1 / 7.4 / 5.9 / 4.7	9.2 / 7.6 / 6.0 / 4.8	9.3 / 7.7 / 6.1 / 4.9
	Heating	H/M/L/SL	m³/min	9.4 / 7.8 / 6.3 / 5.5	9.7 / 8.0 / 6.3 / 5.5	10.1 / 8.4 / 6.7 / 5.7
Sound Power	Cooling	High	dBA	55	56	57
	Heating	High	dBA	55	56	57
Sound Pressure	Cooling	H/M/L/SL	dBA	39 / 33 / 25 / 22	40 / 33 / 26 / 22	41 / 34 / 27 / 23
	Heating	H/M/L/SL	dBA	39 / 34 / 28 / 25	40 / 34 / 28 / 25	41 / 35 / 29 / 26
Refrigerant			Type	R-410A		
Power Supply				1~/220-240V/50Hz		



HEAT PUMP							
Indoor Units				FLXS25B	FLXS35B	FLXS50B	FLXS60B
Dimensions	(Height x Width x Depth)		mm	490x1050x200			
Weight			kg	16.0		17.0	
Air Flow Rate	Cooling	H/M/L/SL	m³/min	7.60 / 6.80 / 6.00 / 5.2	8.60 / 7.60 / 6.60 / 5.6	11.40 / 10.00 / 8.50 / 7.6	12.00 / 10.70 / 9.30 / 8.3
	Heating	H/M/L/SL	m³/min	9.20 / 8.30 / 7.40 / 6.6	9.80 / 8.90 / 8.00 / 7.2	12.1 / 9.8 / 7.5 / 6.8	12.80 / 10.60 / 8.40 / 7.5
Sound Power	Cooling	High	dBA	53.0	54.0	63.0	64.0
	Heating	High	dBA	-	-	62.0	63.0
Sound Pressure	Cooling	H/M/L/SL	dBA	37.0 / 34.0 / 31.0 / 28.0	38.0 / 35.0 / 32.0 / 29.0	47.0 / 43.0 / 39.0 / 36.0	48.0 / 45.0 / 41.0 / 39.0
	Heating	H/M/L/SL	dBA	37.0 / 34.0 / 31.0 / 29.0	39.0 / 36.0 / 33.0 / 30.0	46.0 / 41.0 / 35.0 / 33.0	47.0 / 42.0 / 37.0 / 34.0
Refrigerant			Type	R-410A			
Power Supply				1~/220-240/220-230V/50/60Hz			



HEAT PUMP						
Indoor Units				FVXS25F	FVXS35F	FVXS50F
Dimensions	(Height x Width x Depth)		mm	600x700x210		
Weight			kg	14		
Air Flow Rate	Cooling	H/M/L/SL	m³/min	8.2 / 6.5 / 4.8 / 4.1	8.5 / 6.7 / 4.9 / 4.5	10.7 / 9.2 / 7.8 / 6.6
	Heating	H/M/L/SL	m³/min	8.8 / 6.9 / 5.0 / 4.4	9.4 / 7.3 / 5.2 / 4.7	11.8 / 10.1 / 8.5 / 7.1
Sound Power	Cooling	High	dBA	54	55	56
	Heating	High	dBA	54	55	57
Sound Pressure	Cooling	H/M/L/SL	dBA	38 / 32 / 26 / 23	39 / 33 / 27 / 24	44 / 40 / 36 / 32
	Heating	H/M/L/SL	dBA	38 / 32 / 26 / 23	39 / 33 / 27 / 24	45 / 40 / 36 / 32
Refrigerant			Type	R-410A		
Power Supply				1~/220-240V/50Hz		



HEAT PUMP						
Indoor Units				FVXG25K	FVXG35K	FVXG50K
Dimensions	(Height x Width x Depth)		mm	600x950x215		
Weight			kg	14		
Sound Power	Cooling	High	dBA	54	55	56
	Heating	High	dBA	55	56	58
Sound Pressure	Cooling	H/M/L/SL	dBA	38 / 32 / 26 / 23	39 / 33 / 27 / 24	44 / 40 / 36 / 32
	Heating	H/M/L/SL/Radiant	dBA	39 / 32 / 26 / 22 / 19	40 / 33 / 27 / 23 / 19	46 / 40 / 34 / 30 / 26
Refrigerant			Type	R-410A		
Power Supply				1~/220-240V/50Hz		



HEAT PUMP						
Indoor Units				FDXS25E	FDXS35E	
Dimensions	(Height x Width x Depth)		mm	200x700x620		
Weight			kg	21.0		
Air Flow Rate	Cooling	H/M/L/SL	m³/min	8.7 / 8.0 / 7.3 / 6.2		
	Heating	H/M/L/SL	m³/min	8.7 / 8.0 / 7.3 / 6.2		
Sound Power	Cooling	High	dBA	53.0		
	Heating	High	dBA	53.0		
Sound Pressure	Cooling	H/M/L/SL	dBA	35.0 / 33.0 / 31.0 / 29.0		
	Heating	H/M/L/SL	dBA	35.0 / 33.0 / 31.0 / 29.0		
Refrigerant			Type	R-410A		
Power Supply				1~/220-240/220-230V/50/60Hz		



HEAT PUMP					
Indoor Units				FDXS50C	FDXS60C
Dimensions	(Height x Width x Depth)	mm		200x900x620	200x1100x620
Weight		kg		27.0	30.0
Air Flow Rate	Cooling	H/M/LSL	m³/min	12.0 / 11.0 / 10.0 / 8.4	16.0 / 14.8 / 13.5 / 11.2
	Heating	H/M/LSL	m³/min	12.0 / 11.0 / 10.0 / 8.4	16.0 / 14.8 / 13.5 / 11.2
Sound Power	Cooling	High	dBA	55.0	56.0
	Heating	High	dBA	55.0	56.0
Sound Pressure	Cooling	H/M/LSL	dBA	37.0 / 35.0 / 33.0 / 31.0	38.0 / 36.0 / 34.0 / 32.0
	Heating	H/M/LSL	dBA	37.0 / 35.0 / 33.0 / 31.0	38.0 / 36.0 / 34.0 / 32.0
Refrigerant		Type		R-410A	
Power Supply				220-240/220-230V/50/60Hz	



HEAT PUMP					
Indoor Units				FDBQ25B	
Dimensions	(Height x Width x Depth)	mm		230x652x502	
Weight		kg		17.0	
Air Flow Rate	Cooling	High/Low	m³/min	6.50 / 5.20	
	Heating	High/Low	m³/min	6.95 / 5.20	
Sound Power	Cooling	High/Low	dBA	55.0 / 49.0	
	Heating	High/Low	dBA	55.0 / 49.0	
Sound Pressure	Cooling	High/Low	dBA	35.0 / 28.0	
	Heating	High/Low	dBA	35.0 / 29.0	
Refrigerant		Type		R-410A	
Power Supply				1~/230V/50Hz	



HEAT PUMP						
Indoor Units				FBQ35C	FBQ50C	FBQ60C
Dimensions	(Height x Width x Depth)	mm		300x700x700		
Weight		kg		25	25	34
Air Flow Rate	Cooling	High/Low	m³/min	16 / 11	16 / 11	18 / 15
	Heating	High/Low	m³/min	16 / 11	16 / 11	18 / 15
Sound Power	Cooling	High	dBA	63	63	57
Sound Pressure	Cooling	High/Low	dBA	37 / 29		
	Heating	High/Low	dBA	37 / 29		
Refrigerant		Type		R-410A		
Power Supply				1~/230V/50Hz		



HEAT PUMP							
Indoor Units				FFQ25BV	FFQ35BV	FFQ50BV	FFQ60BV
Dimensions	(Height x Width x Depth)	mm		286x575x575			
Weight		kg		17.5			
Air Flow Rate	Cooling	High/Low	m³/min	9.0 / 6.5	10.0 / 6.5	12.0 / 8.0	15.0 / 10.0
	Heating	High/Low	m³/min	9.0 / 6.5	10.0 / 6.5	12.0 / 8.0	15.0 / 10.0
Sound Power	Cooling	High	dBA	46.5	49.0	53.0	58.0
Sound Pressure	Cooling	High/Low	dBA	29.5 / 24.5	32.0 / 25.0	36.0 / 27.0	41.0 / 32.0
	Heating	High/Low	dBA	29.5 / 24.5	32.0 / 25.0	36.0 / 27.0	41.0 / 32.0
Refrigerant		Type		R-410A			
Power Supply				1~/230V/50Hz			



HEAT PUMP						
Indoor Units				FCQ35C8	FCQ50C8	FCQ60C8
Dimensions	(Height x Width x Depth)		mm	204x840x840		
Weight			kg	19		
Air Flow Rate	Cooling	High/Low	m³/min	10.5 / 8.5	12.5 / 8.5	13.5 / 8.5
	Heating	High/Low	m³/min	12.5 / 10.0	12.5 / 8.5	13.5 / 8.5
Sound Power	Cooling	High	dB(A)	49		51
	Heating	High/Low	dB(A)	31 / 27		33 / 28
Sound Pressure	Cooling	High/Low	dB(A)	31 / 27		33 / 28
	Heating	High/Low	dB(A)	31 / 27		33 / 28
Refrigerant			Type	R-410A		
Power Supply				1~/220-240V/50/60Hz		



HEAT PUMP						
Indoor Units				FHQ35B	FHQ50B	FHQ60B
Dimensions	(Height x Width x Depth)		mm	195x960x680		
Weight			kg	24.0	25.0	27.0
Air Flow Rate	Cooling	High/Low	m³/min	13.0 / 10.0		17.0 / 13.0
	Heating	High/Low	m³/min	13.0 / 10.0		16.0 / 13.0
Sound Power	Cooling	High/Low	dB(A)	53.0 / 48.0	54.0 / 49.0	55.0 / 49.0
	Heating	High/Low	dB(A)	53.0 / 48.0	54.0 / 49.0	55.0 / 49.0
Sound Pressure	Cooling	High/Low	dB(A)	37.0 / 32.0	38.0 / 33.0	39.0 / 33.0
	Heating	High/Low	dB(A)	37.0 / 32.0	38.0 / 33.0	39.0 / 33.0
Refrigerant			Type	R-410A		
Power Supply				1~/220-240V/50Hz		



HEAT PUMP				INVERTER		
Outdoor Unit				2MXS40H	2MXS50H	3MXS52E
Dimensions	(Height x Width x Depth)		mm	550x765x285		
Weight			kg	38	42	49
Operation Range	Cooling	Min~Max	°CDB	10~46		-10~46
	Heating	Min~Max	°CWB	-15~24		-15~15.5
Sound Power (Nom)	Cooling		dB(A)	62	63	59
Sound Pressure (High)	Cooling		dB(A)	47	48	46
	Heating		dB(A)	48	50	47
Refrigerant			Type	R-410A		
Power Supply				1~/220-240V/50Hz		1~/230V/50Hz
Piping connections	Liquid (OD)/Gas/Drain		mm	2x6.4 / 2x9.5	2x6.4 / 9.5 12.7	3x6.4 / 2x9.5 12.9
Piping Length (Maximum)			m	30 (total) 20 (for 1 room)		50 (total) 25 (for 1 room)
Max Installation Height Difference			m	15		



HEAT PUMP				INVERTER			
Outdoor Unit				3MXS68G	4MXS68F	4MXS80E	5MXS90E
Dimension	HxWxD		mm	735x936x300	735x936x300	770x900x320	770x900x320
Weight			kg	58	58	72	73
Operation range	Cooling	Min~Max	°CDB	-10~46	-10~46	-10~46	-10~46
	Heating	Min~Max	°CDB	-15~15.5	-15~15.5	-15~15.5	-15~15.5
Sound Power (Nom)	Cooling		dB(A)	61	61	62	66
Sound Pressure (high)	Cooling		dB(A)	48	48		52
	Heating		dB(A)	49	49		52
Refrigerant			Type	R-410A			
Power Supply				1~/230V/50Hz			
Piping Connection	Liquid (OD)/Gas		mm	3x6.4 / 9.5 2x12.7	4x6.4 / 2x3.5 2x14.7	4x6.4 / 9.5 12.7 2x15.9	5x6.4 / 2x9.5 12.7 2x15.9
Piping Length (Maximum)			m	60 (total) 25 (for 1 room)	60 (total) 25 (for 1 room)	70 (total) 25 (for 1 room)	75 (total) 25 (for 1 room)
Max Installation Height Difference			m	15			

Combination tables

Multi Inverter heat pump

COOLING												
OUTDOOR UNIT	INDOOR UNIT	COOLING CAPACITY (kW)		TOTAL CAPACITY (kW)			POWER INPUT COOLING (kW)			EER	ENERGY LABEL	AEC
		A ROOM	B ROOM	Min.	Nom.	Max.	Min.	Nom.	Max.			
2MXS40H	2.0	2.00	---	1.45	2.00	2.40	0.320	0.450	0.590	4.44	A	225
	2.5	2.50	---	1.45	2.50	3.00	0.320	0.620	0.820	4.03	A	310
	3.5	3.50	---	1.45	3.50	4.00	0.320	1.080	1.410	3.24	A	540
	2.0+2.0	2.00	2.00	1.65	4.00	4.10	0.300	1.090	1.130	3.67	A	545
	2.0+2.5	1.85	2.15	1.65	4.00	4.20	0.300	1.080	1.190	3.70	A	540
	2.0+3.5	1.75	2.25	1.65	4.00	4.40	0.300	1.060	1.310	3.77	A	530
	2.5+2.5	2.00	2.00	1.65	4.00	4.30	0.300	1.070	1.240	3.74	A	535
	2.5+3.5	1.80	2.20	1.65	4.00	4.50	0.300	1.050	1.350	3.81	A	525

HEATING											
OUTDOOR UNIT	INDOOR UNIT	HEATING CAPACITY (kW)		TOTAL CAPACITY (kW)			POWER INPUT HEATING (kW)			COP	ENERGY LABEL
		A ROOM	B ROOM	Min.	Nom.	Max.	Min.	Nom.	Max.		
2MXS40H	2.0	3.00	---	1.20	3.00	3.70	0.290	0.850	1.270	3.53	B
	2.5	3.40	---	1.20	3.40	4.10	0.290	1.060	1.520	3.21	C
	3.5	3.80	---	1.20	3.80	4.40	0.290	1.290	1.730	2.95	D
	2.0+2.0	2.10	2.10	1.50	4.20	4.60	0.270	1.010	1.170	4.16	A
	2.0+2.5	2.10	2.30	1.50	4.40	4.70	0.270	1.080	1.210	4.07	A
	2.0+3.5	2.00	2.40	1.50	4.40	4.70	0.260	1.060	1.190	4.15	A
	2.5+2.5	2.20	2.20	1.50	4.40	4.70	0.270	1.070	1.200	4.11	A
	2.5+3.5	2.05	2.35	1.50	4.40	4.70	0.260	1.050	1.180	4.19	A

COOLING												
OUTDOOR UNIT	INDOOR UNIT	COOLING CAPACITY (kW)		TOTAL CAPACITY (kW)			POWER INPUT COOLING (kW)			EER	ENERGY LABEL	AEC
		A ROOM	B ROOM	Min.	Nom.	Max.	Min.	Nom.	Max.			
2MXS50H	2.0	2.00	---	1.53	2.00	2.60	0.330	0.470	0.690	4.26	A	235
	2.5	2.50	---	1.53	2.50	3.10	0.330	0.660	0.920	3.79	A	330
	3.5	3.50	---	1.53	3.50	4.00	0.330	1.090	1.420	3.21	A	545
	4.2	4.20	---	1.55	4.20	4.70	0.330	1.530	2.050	2.75	D	765
	5.0	5.00	---	1.57	5.00	5.10	0.330	2.060	2.170	2.43	E	1,030
	2.0+2.0	2.00	2.00	1.81	4.00	4.90	0.330	1.050	1.530	3.81	A	525
	2.0+2.5	2.00	2.50	1.81	4.50	5.00	0.330	1.290	1.600	3.49	A	645
	2.0+3.5	1.82	3.18	1.81	5.00	5.30	0.330	1.560	1.760	3.21	A	780
	2.0+4.2	1.61	3.39	1.81	5.00	5.40	0.330	1.540	1.800	3.25	A	770
	2.0+5.0	1.43	3.57	1.81	5.00	5.40	0.330	1.470	1.720	3.40	A	735
	2.5+2.5	2.50	2.50	1.81	5.00	5.20	0.330	1.560	1.710	3.21	A	780
	2.5+3.5	2.08	2.92	1.81	5.00	5.30	0.330	1.530	1.760	3.27	A	765
	2.5+4.2	1.87	3.13	1.81	5.00	5.40	0.330	1.500	1.800	3.33	A	750
	2.5+5.0	1.67	3.33	1.81	5.00	5.40	0.330	1.470	1.730	3.40	A	735
	3.5+3.5	2.50	2.50	1.81	5.00	5.30	0.330	1.500	1.720	3.33	A	750
	3.5+4.2	2.27	2.73	1.81	5.00	5.40	0.330	1.470	1.770	3.40	A	735
	3.5+5.0	2.06	2.94	1.81	5.00	5.40	0.330	1.440	1.700	3.47	A	720
	4.2+4.2	2.50	2.50	1.81	5.00	5.40	0.330	1.440	1.730	3.47	A	720

HEATING											
OUTDOOR UNIT	INDOOR UNIT	HEATING CAPACITY (kW)		TOTAL CAPACITY (kW)			POWER INPUT HEATING (kW)			COP	ENERGY LABEL
		A ROOM	B ROOM	Min.	Nom.	Max.	Min.	Nom.	Max.		
2MXS50H	2.0	3.00	---	1.21	3.00	3.70	0.270	0.820	1.140	3.66	A
	2.5	3.40	---	1.21	3.40	4.10	0.250	0.980	1.330	3.47	B
	3.5	4.00	---	1.21	4.00	4.60	0.250	1.240	1.530	3.23	C
	4.2	4.70	---	1.21	4.70	5.10	0.250	1.560	1.770	3.01	D
	5.0	5.40	---	1.33	5.40	5.60	0.270	1.830	1.980	2.95	D
	2.0+2.0	2.65	2.65	1.28	5.30	5.70	0.240	1.340	1.530	3.96	A
	2.0+2.5	2.44	3.06	1.28	5.50	5.80	0.240	1.420	1.560	3.87	A
	2.0+3.5	2.04	3.56	1.34	5.60	5.90	0.250	1.440	1.570	3.89	A
	2.0+4.2	1.84	3.86	1.35	5.70	6.00	0.250	1.470	1.590	3.88	A
	2.0+5.0	1.63	4.07	1.39	5.70	6.20	0.250	1.370	1.610	4.16	A
	2.5+2.5	2.80	2.80	1.28	5.60	5.80	0.240	1.450	1.550	3.86	A
	2.5+3.5	2.38	3.32	1.34	5.70	6.00	0.250	1.480	1.640	3.85	A
	2.5+4.2	2.13	3.57	1.35	5.70	6.10	0.250	1.450	1.660	3.93	A
	2.5+5.0	1.90	3.80	1.45	5.70	6.30	0.260	1.360	1.650	4.19	A
	3.5+3.5	2.85	2.85	1.40	5.70	6.10	0.250	1.460	1.650	3.90	A
	3.5+4.2	2.59	3.11	1.41	5.70	6.20	0.250	1.420	1.660	4.01	A
	3.5+5.0	2.35	3.35	1.45	5.70	6.40	0.250	1.350	1.650	4.22	A
	4.2+4.2	2.85	2.85	1.42	5.70	6.30	0.250	1.400	1.680	4.07	A

COOLING													
OUTDOOR UNIT	INDOOR UNIT	COOLING CAPACITY (kW)			TOTAL CAPACITY (kW)			POWER INPUT COOLING (W)			EER	ENERGY LABEL	AEC (kWh)
		A ROOM	B ROOM	C ROOM	Min.	Nom.	Max.	Min.	Nom.	Max.			
3MXS52E	2.0	2.00	---	---	1.76	2.00	2.84	350	460	740	4.35	A	230
	2.5	2.50	---	---	1.76	2.50	3.12	350	620	880	4.03	A	310
	3.5	3.50	---	---	1.76	3.50	4.18	350	970	1290	3.61	A	485
	4.2	4.20	---	---	1.76	4.20	4.70	350	1240	1640	3.39	A	620
	5.0	5.00	---	---	1.79	5.00	5.40	350	1750	2030	2.86	C	875
	2.0+2.0	2.00	2.00	---	1.88	4.00	5.96	350	950	1910	4.21	A	475
	2.0+2.5	2.00	2.50	---	1.88	4.50	6.23	350	1180	2140	3.81	A	590
	2.0+3.5	1.89	3.31	---	1.88	5.20	6.24	350	1550	2070	3.35	A	775
	2.0+4.2	1.68	3.52	---	1.88	5.20	6.25	350	1550	2070	3.35	A	775
	2.0+5.0	1.49	3.71	---	1.88	5.20	6.47	350	1420	2150	3.66	A	710
	2.5+2.5	2.50	2.50	---	1.88	5.00	6.23	350	1450	2140	3.45	A	725
	2.5+3.5	2.17	3.03	---	1.88	5.20	6.35	350	1550	2250	3.35	A	775
	2.5+4.2	1.94	3.26	---	1.88	5.20	6.36	350	1550	2250	3.35	A	775
	2.5+5.0	1.73	3.47	---	1.88	5.20	6.47	350	1420	2070	3.66	A	710
	3.5+3.5	2.60	2.60	---	1.88	5.20	6.40	350	1550	2250	3.35	A	775
	3.5+4.2	2.36	2.84	---	1.88	5.20	6.41	350	1550	2250	3.35	A	775
	3.5+5.0	2.14	3.06	---	1.88	5.20	6.49	350	1420	2090	3.66	A	710
	4.2+4.2	2.60	2.60	---	1.88	5.20	6.42	350	1550	2250	3.35	A	775
	2.0+2.0+2.0	1.73	1.73	1.73	1.86	5.19	7.04	350	1240	2160	4.19	A	620
	2.0+2.0+2.5	1.60	1.60	1.99	1.86	5.19	7.04	350	1240	2160	4.19	A	620
	2.0+2.0+3.5	1.38	1.38	2.43	1.95	5.19	7.06	370	1240	2160	4.19	A	620
	2.0+2.0+4.2	1.27	1.27	2.66	1.95	5.20	7.07	370	1240	2160	4.19	A	620
	2.0+2.0+5.0	1.16	1.16	2.88	2.11	5.20	7.30	380	1220	2260	4.26	A	610
	2.0+2.5+2.5	1.49	1.85	1.85	1.86	5.19	7.04	350	1240	2160	4.19	A	620
	2.0+2.5+3.5	1.30	1.63	2.27	1.95	5.20	7.06	370	1240	2160	4.19	A	620
	2.0+2.5+4.2	1.20	1.49	2.51	1.95	5.20	7.07	370	1240	2160	4.19	A	620
	2.0+3.5+3.5	1.16	2.02	2.02	1.95	5.20	7.07	370	1240	2160	4.19	A	620
	2.5+2.5+2.5	1.73	1.73	1.73	1.95	5.19	7.04	370	1240	2160	4.19	A	620
	2.5+2.5+3.5	1.53	1.53	2.14	1.95	5.20	7.06	370	1230	2160	4.23	A	615

HEATING												
OUTDOOR UNIT	INDOOR UNIT	HEATING CAPACITY (kW)			TOTAL CAPACITY (kW)			POWER INPUT HEATING (W)			COP	ENERGY LABEL
		A ROOM	B ROOM	C ROOM	Min.	Nom.	Max.	Min.	Nom.	Max.		
3MXS52E	2.0	2.72	---	---	1.21	2.72	3.75	300	720	1200	3.78	A
	2.5	3.40	---	---	1.21	3.40	4.00	300	990	1260	3.43	B
	3.5	4.20	---	---	1.21	4.20	4.82	300	1390	1680	3.02	D
	4.2	4.70	---	---	1.21	4.70	5.87	300	1700	2400	2.76	E
	5.0	5.80	---	---	1.33	5.80	6.79	300	2160	2590	2.69	E
	2.0+2.0	3.05	3.05	---	1.28	6.10	7.00	310	1700	2280	3.59	B
	2.0+2.5	2.78	3.47	---	1.28	6.25	7.00	310	1750	2280	3.57	B
	2.0+3.5	2.38	4.17	---	1.34	6.55	7.04	310	1860	2280	3.52	B
	2.0+4.2	2.16	4.54	---	1.34	6.70	7.05	310	1930	2270	3.47	B
	2.0+5.0	1.94	4.86	---	1.39	6.80	7.20	310	1870	2320	3.64	A
	2.5+2.5	3.25	3.25	---	1.28	6.50	7.00	310	1860	2310	3.49	B
	2.5+3.5	2.79	3.91	---	1.34	6.70	7.19	310	1930	2360	3.47	B
	2.5+4.2	2.54	4.26	---	1.34	6.80	7.21	310	1930	2350	3.52	B
	2.5+5.0	2.27	4.53	---	1.45	6.80	7.35	310	1870	2320	3.64	A
	3.5+3.5	3.40	3.40	---	1.40	6.80	7.22	310	1970	2350	3.45	B
	3.5+4.2	3.09	3.71	---	1.40	6.80	7.24	310	1970	2350	3.45	B
	3.5+5.0	2.80	4.00	---	1.45	6.80	7.50	310	1830	2310	3.72	A
	4.2+4.2	3.40	3.40	---	1.40	6.80	7.26	310	1960	2340	3.47	B
	2.0+2.0+2.0	2.26	2.26	2.26	1.34	6.78	8.02	320	1570	2140	4.32	A
	2.0+2.0+2.5	2.09	2.09	2.60	1.34	6.78	8.02	320	1570	2140	4.32	A
	2.0+2.0+3.5	1.80	1.80	3.18	1.45	6.78	8.05	320	1560	2140	4.35	A
	2.0+2.0+4.2	1.66	1.66	3.48	1.45	6.80	8.06	320	1560	2140	4.36	A
	2.0+2.0+5.0	1.51	1.51	3.78	1.67	6.80	8.27	320	1640	2110	4.15	A
	2.0+2.5+2.5	1.94	2.42	2.42	1.34	6.78	8.02	320	1570	2140	4.32	A
	2.0+2.5+3.5	1.70	2.13	2.97	1.57	6.80	8.05	320	1560	2140	4.36	A
	2.0+2.5+4.2	1.56	1.95	3.28	1.56	6.80	8.06	320	1560	2140	4.36	A
	2.0+3.5+3.5	1.52	2.64	2.64	1.56	6.80	8.08	320	1560	2140	4.36	A
	2.5+2.5+2.5	2.26	2.26	2.26	1.45	6.78	8.02	320	1570	2140	4.32	A
	2.5+2.5+3.5	2.00	2.00	2.80	1.57	6.80	8.05	320	1560	2140	4.36	A

COOLING													
OUTDOOR UNIT	INDOOR UNIT	COOLING CAPACITY (kW)			TOTAL CAPACITY (kW)			POWER INPUT COOLING (kW)			EER	ENERGY LABEL	AEC (kWh)
		A ROOM	B ROOM	C ROOM	Min.	Nom.	Max.	Min.	Nom.	Max.			
3MXS68G	2.0	2.00	---	---	1.95	2.00	2.63	0.440	0.470	0.620	4.26	A	235
	2.5	2.50	---	---	1.95	2.50	3.37	0.460	0.590	0.850	4.24	A	295
	3.5	3.50	---	---	1.95	3.50	4.76	0.470	0.910	1.470	3.85	A	455
	4.2	4.20	---	---	1.95	4.20	5.02	0.470	1.210	1.620	3.47	A	605
	5.0	5.00	---	---	1.96	5.00	5.91	0.450	1.710	2.200	2.92	C	855
	6.0	6.00	---	---	1.96	6.00	6.38	0.440	2.050	2.320	2.93	C	1,025
	2.0+2.0	2.00	2.00	---	1.97	4.00	5.02	0.430	1.000	1.450	4.00	A	500
	2.0+2.5	2.00	2.50	---	1.97	4.50	5.33	0.430	1.200	1.610	3.75	A	600
	2.0+3.5	2.00	3.50	---	1.97	5.50	6.18	0.420	1.660	2.150	3.31	A	830
	2.0+4.2	2.00	4.20	---	1.97	6.20	6.38	0.420	2.090	2.300	2.97	C	1,045
	2.0+5.0	1.94	4.86	---	1.97	6.80	7.12	0.410	2.410	2.650	2.82	C	1,205
	2.0+6.0	1.70	5.10	---	1.98	6.80	7.56	0.400	2.210	2.750	3.08	B	1,105
	2.5+2.5	2.50	2.50	---	1.97	5.00	5.98	0.450	1.460	2.000	3.42	A	730
	2.5+3.5	2.50	3.50	---	1.97	6.00	6.44	0.430	2.060	2.370	2.91	C	1,030
	2.5+4.2	2.50	4.20	---	1.97	6.70	6.81	0.430	2.540	2.670	2.64	D	1,270
	2.5+5.0	2.27	4.53	---	1.97	6.80	7.23	0.400	2.410	2.750	2.82	C	1,205
	2.5+6.0	2.00	4.80	---	1.98	6.80	7.56	0.380	2.210	2.750	3.08	B	1,105
	3.5+3.5	3.40	3.40	---	1.97	6.80	6.99	0.410	2.510	2.660	2.71	D	1,255
	3.5+4.2	3.09	3.71	---	1.97	6.80	7.10	0.410	2.510	2.760	2.71	D	1,255
	3.5+5.0	2.80	4.00	---	1.97	6.80	7.61	0.380	2.410	3.120	2.82	C	1,205
	3.5+6.0	2.51	4.29	---	2.28	6.80	7.91	0.430	2.210	3.060	3.08	B	1,105
	4.2+4.2	3.40	3.40	---	1.97	6.80	7.00	0.410	2.510	2.660	2.71	D	1,255
	4.2+5.0	3.10	3.70	---	1.97	6.80	7.62	0.380	2.410	3.120	2.82	C	1,205
	4.2+6.0	2.80	4.00	---	2.28	6.80	7.92	0.430	2.210	3.060	3.08	B	1,105
	5.0+5.0	3.40	3.40	---	2.36	6.80	8.06	0.470	2.310	3.350	2.94	C	1,155
	5.0+6.0	3.09	3.71	---	2.49	6.80	8.28	0.480	2.120	3.280	3.21	A	1,060
	2.0+2.0+2.0	2.00	2.00	2.00	1.98	6.00	6.51	0.420	1.640	1.890	3.66	A	820
	2.0+2.0+2.5	2.00	2.00	2.50	1.98	6.50	6.89	0.420	1.890	2.120	3.44	A	945
	2.0+2.0+3.5	1.81	1.81	3.18	1.98	6.80	7.25	0.410	2.070	2.350	3.29	A	1,035
	2.0+2.0+4.2	1.66	1.66	3.48	1.98	6.80	7.46	0.410	2.070	2.500	3.29	A	1,035
	2.0+2.0+5.0	1.51	1.51	3.78	1.98	6.80	7.85	0.390	2.020	2.690	3.37	A	1,010
	2.0+2.0+6.0	1.36	1.36	4.08	2.33	6.80	8.11	0.440	1.830	2.640	3.72	A	915
	2.0+2.5+2.5	1.94	2.43	2.43	1.98	6.80	7.10	0.410	2.070	2.260	3.29	A	1,035
	2.0+2.5+3.5	1.70	2.13	2.97	1.98	6.80	7.59	0.390	2.070	2.590	3.29	A	1,035
	2.0+2.5+4.2	1.56	1.95	3.29	1.98	6.80	7.78	0.390	2.070	2.750	3.29	A	1,035
	2.0+2.5+5.0	1.43	1.79	3.58	1.98	6.80	7.92	0.390	2.020	2.740	3.37	A	1,010
	2.0+2.5+6.0	1.30	1.62	3.88	2.33	6.80	8.38	0.450	1.830	2.840	3.72	A	915
	2.0+3.5+3.5	1.52	2.64	2.64	1.98	6.80	7.91	0.400	2.070	2.850	3.29	A	1,035
	2.0+3.5+4.2	1.40	2.45	2.95	1.98	6.80	8.09	0.400	2.070	3.010	3.29	A	1,035
	2.0+3.5+5.0	1.30	2.27	3.23	2.30	6.80	8.41	0.440	2.020	3.170	3.37	A	1,010
	2.0+4.2+4.2	1.30	2.75	2.75	1.98	6.80	8.21	0.400	2.070	3.110	3.29	A	1,035
	2.5+2.5+2.5	2.26	2.26	2.26	1.98	6.78	7.38	0.410	2.070	2.450	3.28	A	1,035
	2.5+2.5+3.5	2.00	2.00	2.80	1.98	6.80	7.78	0.390	2.070	2.750	3.29	A	1,035
	2.5+2.5+4.2	1.85	1.85	3.10	1.98	6.80	7.96	0.390	2.070	2.900	3.29	A	1,035
	2.5+2.5+5.0	1.70	1.70	3.40	2.30	6.80	8.28	0.440	2.020	3.060	3.37	A	1,010
	2.5+2.5+6.0	1.55	1.55	3.70	2.44	6.80	8.57	0.440	1.830	3.000	3.72	A	915
	2.5+3.5+3.5	1.78	2.51	2.51	2.29	6.80	8.14	0.440	2.070	3.060	3.29	A	1,035
	2.5+3.5+4.2	1.67	2.33	2.80	2.29	6.80	8.26	0.440	2.070	3.170	3.29	A	1,035
	2.5+3.5+5.0	1.55	2.16	3.09	2.51	6.80	8.57	0.460	1.980	3.330	3.43	A	990
	2.5+4.2+4.2	1.56	2.62	2.62	2.29	6.80	8.32	0.440	2.070	3.220	3.29	A	1,035
3.5+3.5+3.5	2.26	2.26	2.26	2.40	6.78	8.42	0.430	2.070	3.330	3.28	A	1,035	

HEATING												
OUTDOOR UNIT	INDOOR UNIT	HEATING CAPACITY (kW)			TOTAL CAPACITY (kW)			POWER INPUT HEATING (kW)			COP	ENERGY LABEL
		A ROOM	B ROOM	C ROOM	Min.	Nom.	Max.	Min.	Nom.	Max.		
3MXS68G	2.0	2.72	---	---	1.51	2.72	3.93	0.440	0.740	1.270	3.68	A
	2.5	3.40	---	---	1.47	3.40	4.13	0.430	1.030	1.370	3.30	C
	3.5	4.30	---	---	1.48	4.30	4.52	0.410	1.420	1.610	3.03	D
	4.2	4.50	---	---	1.48	4.50	4.71	0.410	1.510	1.720	2.98	D
	5.0	5.60	---	---	1.65	5.60	5.76	0.390	2.130	2.260	2.63	E
	6.0	7.90	---	---	1.92	7.90	8.57	0.410	2.650	2.920	2.98	D
	2.0+2.0	3.25	3.25	---	1.62	6.50	7.64	0.380	1.870	2.250	3.48	B
	2.0+2.5	3.04	3.81	---	1.62	6.85	7.81	0.380	2.050	2.330	3.34	C
	2.0+3.5	2.71	4.74	---	1.76	7.45	8.34	0.390	2.340	2.640	3.18	D
	2.0+4.2	2.58	5.42	---	1.76	8.00	8.68	0.390	2.640	2.890	3.03	D
	2.0+5.0	2.46	6.14	---	2.14	8.60	10.15	0.480	2.800	3.260	3.07	D
	2.0+6.0	2.15	6.45	---	2.41	8.60	10.34	0.510	2.430	2.980	3.54	B
	2.5+2.5	3.60	3.60	---	1.62	7.20	8.16	0.380	2.240	2.560	3.21	C
	2.5+3.5	3.29	4.61	---	1.85	7.90	8.68	0.400	2.580	2.890	3.06	D
	2.5+4.2	3.10	5.20	---	1.85	8.30	8.93	0.400	2.800	3.070	2.96	D
	2.5+5.0	2.87	5.73	---	2.23	8.60	10.27	0.490	2.800	3.360	3.07	D
	2.5+6.0	2.53	6.07	---	2.50	8.60	10.46	0.530	2.430	3.010	3.54	B
	3.5+3.5	4.30	4.30	---	2.13	8.60	9.02	0.450	2.930	3.110	2.94	D
	3.5+4.2	3.91	4.69	---	2.13	8.60	9.11	0.450	2.920	3.160	2.95	D
	3.5+5.0	3.54	5.06	---	2.51	8.60	10.48	0.540	2.790	3.400	3.08	D
	3.5+6.0	3.17	5.43	---	2.69	8.60	10.59	0.550	2.420	3.000	3.55	B
	4.2+4.2	4.30	4.30	---	2.13	8.60	9.19	0.450	2.920	3.200	2.95	D
	4.2+5.0	3.93	4.67	---	2.51	8.60	10.49	0.540	2.790	3.470	3.08	D
	4.2+6.0	3.54	5.06	---	2.69	8.60	10.60	0.540	2.420	3.030	3.55	B
	5.0+5.0	4.30	4.30	---	2.88	8.60	10.67	0.630	2.700	3.380	3.19	D
	5.0+6.0	3.91	4.69	---	3.08	8.60	10.66	0.640	2.390	2.960	3.60	B
	2.0+2.0+2.0	2.63	2.63	2.63	1.97	7.89	10.04	0.440	2.050	2.700	3.85	A
	2.0+2.0+2.5	2.54	2.54	3.17	2.06	8.25	10.12	0.450	2.180	2.740	3.78	A
	2.0+2.0+3.5	2.29	2.29	4.02	2.26	8.60	10.22	0.470	2.340	2.880	3.68	A
	2.0+2.0+4.2	2.10	2.10	4.40	2.26	8.60	10.22	0.470	2.340	2.880	3.68	A
	2.0+2.0+5.0	1.91	1.91	4.78	2.66	8.60	10.40	0.580	2.340	2.960	3.68	A
	2.0+2.0+6.0	1.72	1.72	5.16	2.87	8.60	10.53	0.580	2.120	2.670	4.06	A
	2.0+2.5+2.5	2.46	3.07	3.07	2.16	8.60	10.13	0.460	2.350	2.840	3.66	A
	2.0+2.5+3.5	2.15	2.69	3.76	2.35	8.60	10.22	0.490	2.340	2.880	3.68	A
	2.0+2.5+4.2	1.98	2.47	4.15	2.36	8.60	10.23	0.490	2.340	2.870	3.68	A
	2.0+2.5+5.0	1.81	2.26	4.53	2.75	8.60	10.63	0.600	2.320	2.990	3.71	A
	2.0+2.5+6.0	1.64	2.05	4.91	2.96	8.60	10.64	0.600	2.100	2.640	4.10	A
	2.0+3.5+3.5	1.92	3.34	3.34	2.64	8.60	10.35	0.550	2.310	2.930	3.72	A
	2.0+3.5+4.2	1.77	3.10	3.72	2.64	8.60	10.35	0.550	2.310	2.920	3.72	A
	2.0+3.5+5.0	1.64	2.87	4.09	2.94	8.60	10.68	0.620	2.290	3.060	3.76	A
	2.0+4.2+4.2	1.65	3.47	3.47	2.64	8.60	10.36	0.550	2.310	2.920	3.72	A
	2.5+2.5+2.5	2.86	2.86	2.86	2.26	8.58	10.24	0.480	2.350	2.870	3.65	A
	2.5+2.5+3.5	2.53	2.53	3.54	2.45	8.60	10.45	0.510	2.340	2.960	3.68	A
	2.5+2.5+4.2	2.34	2.34	3.93	2.45	8.60	10.46	0.510	2.340	2.960	3.68	A
	2.5+2.5+5.0	2.15	2.15	4.30	2.85	8.60	10.64	0.620	2.290	3.020	3.76	A
	2.5+2.5+6.0	1.95	1.95	4.70	3.06	8.60	10.65	0.620	2.080	2.640	4.13	A
	2.5+3.5+3.5	2.26	3.17	3.17	2.73	8.60	10.58	0.560	2.310	2.960	3.72	A
	2.5+3.5+4.2	2.11	2.95	3.54	2.74	8.60	10.59	0.560	2.310	2.950	3.72	A
	2.5+3.5+5.0	1.95	2.74	3.91	3.13	8.60	10.65	0.640	2.290	2.980	3.76	A
	2.5+4.2+4.2	1.97	3.31	3.31	2.74	8.60	10.59	0.560	2.310	2.950	3.72	A
3.5+3.5+3.5	2.86	2.86	2.86	2.92	8.58	10.63	0.610	2.290	3.030	3.75	A	

COOLING														
OUTDOOR UNIT	INDOOR UNIT	COOLING CAPACITY (kW)				TOTAL CAPACITY (kW)			POWER INPUT COOLING (kW)			EER	ENERGY LABEL	AEC (kWh)
		A ROOM	B ROOM	C ROOM	D ROOM	Min.	Nom.	Max.	Min.	Nom.	Max.			
4MXS68F	2.0	2.00	---	---	---	1.95	2.00	2.63	0.440	0.470	0.620	4.26	A	235
	2.5	2.50	---	---	---	1.95	2.50	3.37	0.460	0.590	0.850	4.24	A	295
	3.5	3.50	---	---	---	1.95	3.50	4.76	0.470	0.910	1.470	3.85	A	455
	4.2	4.20	---	---	---	1.95	4.20	5.02	0.470	1.210	1.620	3.47	A	605
	5.0	5.00	---	---	---	1.96	5.00	5.91	0.450	1.710	2.200	2.92	C	855
	6.0	6.00	---	---	---	1.96	6.00	6.38	0.440	2.050	2.320	2.93	C	1,025
	2.0+2.0	2.00	2.00	---	---	1.97	4.00	5.02	0.430	1.000	1.450	4.00	A	500
	2.0+2.5	2.00	2.50	---	---	1.97	4.50	5.33	0.430	1.200	1.610	3.75	A	600
	2.0+3.5	2.00	3.50	---	---	1.97	5.50	6.18	0.420	1.660	2.150	3.31	A	830
	2.0+4.2	2.00	4.20	---	---	1.97	6.20	6.38	0.420	2.090	2.300	2.97	C	1,045
	2.0+5.0	1.94	4.86	---	---	1.97	6.80	7.12	0.410	2.410	2.650	2.82	C	1,205
	2.0+6.0	1.70	5.10	---	---	1.98	6.80	7.56	0.400	2.210	2.750	3.08	B	1,105
	2.5+2.5	2.50	2.50	---	---	1.97	5.00	5.98	0.450	1.460	2.000	3.42	A	730
	2.5+3.5	2.50	3.50	---	---	1.97	6.00	6.44	0.430	2.060	2.370	2.91	C	1,030
	2.5+4.2	2.50	4.20	---	---	1.97	6.70	6.81	0.430	2.540	2.670	2.64	D	1,270
	2.5+5.0	2.27	4.53	---	---	1.97	6.80	7.23	0.400	2.410	2.750	2.82	C	1,205
	2.5+6.0	2.00	4.80	---	---	1.98	6.80	7.56	0.380	2.210	2.750	3.08	B	1,105
	3.5+3.5	3.40	3.40	---	---	1.97	6.80	6.99	0.410	2.510	2.660	2.71	D	1,255
	3.5+4.2	3.09	3.71	---	---	1.97	6.80	7.10	0.410	2.510	2.760	2.71	D	1,255
	3.5+5.0	2.80	4.00	---	---	1.97	6.80	7.61	0.380	2.410	3.120	2.82	C	1,205
	3.5+6.0	2.51	4.29	---	---	2.28	6.80	7.91	0.430	2.210	3.060	3.08	B	1,105
	4.2+4.2	3.40	3.40	---	---	1.97	6.80	7.00	0.410	2.510	2.660	2.71	D	1,255
	4.2+5.0	3.10	3.70	---	---	1.97	6.80	7.62	0.380	2.410	3.120	2.82	C	1,205
	4.2+6.0	2.80	4.00	---	---	2.28	6.80	7.92	0.430	2.210	3.060	3.06	B	1,105
	5.0+5.0	3.40	3.40	---	---	2.36	6.80	8.06	0.470	2.310	3.350	2.94	C	1,155
	5.0+6.0	3.09	3.71	---	---	2.49	6.80	8.28	0.480	2.120	3.280	3.21	A	1,060
	2.0+2.0+2.0	2.00	2.00	2.00	---	1.98	6.00	6.51	0.420	1.640	1.890	3.66	A	820
	2.0+2.0+2.5	2.00	2.00	2.50	---	1.98	6.50	6.89	0.420	1.890	2.120	3.44	A	945
	2.0+2.0+3.5	1.81	1.81	3.18	---	1.98	6.80	7.25	0.410	2.070	2.350	3.29	A	1,035
	2.0+2.0+4.2	1.66	1.66	3.48	---	1.98	6.80	7.46	0.410	2.070	2.500	3.29	A	1,035
	2.0+2.0+5.0	1.51	1.51	3.78	---	1.98	6.80	7.85	0.390	2.020	2.690	3.37	A	1,010
	2.0+2.0+6.0	1.36	1.36	4.08	---	2.33	6.80	8.11	0.440	1.830	2.640	3.72	A	915
	2.0+2.5+2.5	1.94	2.43	2.43	---	1.98	6.80	7.10	0.410	2.070	2.260	3.29	A	1,035
	2.0+2.5+3.5	1.70	2.13	2.97	---	1.98	6.80	7.59	0.390	2.070	2.590	3.29	A	1,035
	2.0+2.5+4.2	1.56	1.95	3.29	---	1.98	6.80	7.78	0.390	2.070	2.750	3.29	A	1,035
	2.0+2.5+5.0	1.43	1.79	3.58	---	1.98	6.80	7.92	0.390	2.020	2.740	3.37	A	1,010
	2.0+2.5+6.0	1.30	1.62	3.88	---	2.33	6.80	8.38	0.450	1.830	2.840	3.72	A	915
	2.0+3.5+3.5	1.52	2.64	2.64	---	1.98	6.80	7.91	0.400	2.070	2.850	3.29	A	1,035
	2.0+3.5+4.2	1.40	2.45	2.95	---	1.98	6.80	8.09	0.400	2.070	3.010	3.29	A	1,035
	2.0+3.5+5.0	1.30	2.27	3.23	---	2.30	6.80	8.41	0.440	2.020	3.170	3.37	A	1,010
	2.0+4.2+4.2	1.30	2.75	2.75	---	1.98	6.80	8.21	0.400	2.070	3.110	3.29	A	1,035
	2.5+2.5+2.5	2.26	2.26	2.26	---	1.98	6.78	7.38	0.410	2.070	2.450	3.28	A	1,035
	2.5+2.5+3.5	2.00	2.00	2.80	---	1.98	6.80	7.78	0.390	2.070	2.750	3.29	A	1,035
	2.5+2.5+4.2	1.85	1.85	3.10	---	1.98	6.80	7.96	0.390	2.070	2.900	3.29	A	1,035
	2.5+2.5+5.0	1.70	1.70	3.40	---	2.30	6.80	8.28	0.440	2.020	3.060	3.37	A	1,010
	2.5+2.5+6.0	1.55	1.55	3.70	---	2.44	6.80	8.57	0.440	1.830	3.000	3.72	A	915
	2.5+3.5+3.5	1.78	2.51	2.51	---	2.29	6.80	8.14	0.440	2.070	3.060	3.29	A	1,035
	2.5+3.5+4.2	1.67	2.33	2.80	---	2.29	6.80	8.26	0.440	2.070	3.170	3.29	A	1,035
	2.5+3.5+5.0	1.55	2.16	3.09	---	2.51	6.80	8.57	0.460	1.980	3.330	3.43	A	990
	2.5+4.2+4.2	1.56	2.62	2.62	---	2.29	6.80	8.32	0.440	2.070	3.220	3.29	A	1,035
3.5+3.5+3.5	2.26	2.26	2.26	---	2.40	6.78	8.42	0.430	2.070	3.330	3.28	A	1,035	
2.0+2.0+2.0+2.0	1.70	1.70	1.70	1.70	1.99	6.80	7.63	0.410	1.750	2.190	3.89	A	875	
2.0+2.0+2.0+2.5	1.60	1.60	1.60	2.00	1.99	6.80	7.79	0.390	1.730	2.290	3.93	A	865	
2.0+2.0+2.0+3.5	1.43	1.43	1.43	2.51	1.99	6.80	8.17	0.400	1.710	2.530	3.98	A	855	
2.0+2.0+2.0+4.2	1.33	1.33	1.33	2.81	1.99	6.80	8.32	0.400	1.710	2.630	3.98	A	855	
2.0+2.0+2.0+5.0	1.24	1.24	1.24	3.08	2.47	6.80	8.74	0.460	1.670	2.930	4.07	A	835	
2.0+2.0+2.5+2.5	1.51	1.51	1.89	1.89	1.99	6.80	7.94	0.400	1.750	2.380	3.89	A	875	
2.0+2.0+2.5+3.5	1.36	1.36	1.70	2.38	2.34	6.80	8.32	0.450	1.730	2.630	3.93	A	865	
2.0+2.0+2.5+4.2	1.27	1.27	1.59	2.67	2.34	6.80	8.47	0.450	1.730	2.740	3.93	A	865	
2.0+2.0+3.5+3.5	1.24	1.24	2.16	2.16	2.46	6.80	8.61	0.450	1.710	2.840	3.98	A	855	
2.0+2.5+2.5+2.5	1.43	1.79	1.79	1.79	1.99	6.80	8.17	0.400	1.750	2.530	3.89	A	875	
2.0+2.5+2.5+3.5	1.30	1.62	1.62	2.26	2.34	6.80	8.46	0.450	1.730	2.740	3.93	A	865	
2.5+2.5+2.5+2.5	1.70	1.70	1.70	1.70	2.34	6.80	8.39	0.460	1.710	2.680	3.98	A	855	
2.5+2.5+2.5+3.5	1.55	1.55	1.55	2.15	2.46	6.80	8.73	0.460	1.700	2.950	4.00	A	850	

HEATING													
OUTDOOR UNIT	INDOOR UNIT	HEATING CAPACITY (kW)				TOTAL CAPACITY (kW)			POWER INPUT HEATING (kW)			COP	ENERGY LABEL
		A ROOM	B ROOM	C ROOM	D ROOM	Min.	Nom.	Max.	Min.	Nom.	Max.		
4MXS68F	2.0	2.72	---	---	---	1.51	2.72	3.93	0.440	0.740	1.270	3.68	A
	2.5	3.40	---	---	---	1.47	3.40	4.13	0.430	1.030	1.370	3.30	C
	3.5	4.30	---	---	---	1.48	4.30	4.52	0.410	1.420	1.610	3.03	D
	4.2	4.50	---	---	---	1.48	4.50	4.71	0.410	1.510	1.720	2.98	D
	5.0	5.60	---	---	---	1.65	5.60	5.76	0.390	2.130	2.260	2.63	E
	6.0	7.90	---	---	---	1.92	7.90	8.57	0.410	2.650	2.920	2.98	D
	2.0+2.0	3.25	3.25	---	---	1.62	6.50	7.64	0.380	1.870	2.250	3.48	B
	2.0+2.5	3.04	3.81	---	---	1.62	6.85	7.81	0.380	2.050	2.330	3.34	C
	2.0+3.5	2.71	4.74	---	---	1.76	7.45	8.34	0.390	2.340	2.640	3.18	D
	2.0+4.2	2.58	5.42	---	---	1.76	8.00	8.68	0.390	2.640	2.890	3.03	D
	2.0+5.0	2.46	6.14	---	---	2.14	8.60	10.15	0.480	2.800	3.260	3.07	D
	2.0+6.0	2.15	6.45	---	---	2.41	8.60	10.34	0.510	2.430	2.980	3.54	B
	2.5+2.5	3.60	3.60	---	---	1.62	7.20	8.16	0.380	2.240	2.560	3.21	C
	2.5+3.5	3.29	4.61	---	---	1.85	7.90	8.68	0.400	2.580	2.890	3.06	D
	2.5+4.2	3.10	5.20	---	---	1.85	8.30	8.93	0.400	2.800	3.070	2.96	D
	2.5+5.0	2.87	5.73	---	---	2.23	8.60	10.27	0.490	2.800	3.360	3.07	D
	2.5+6.0	2.53	6.07	---	---	2.50	8.60	10.46	0.530	2.430	3.010	3.54	B
	3.5+3.5	4.30	4.30	---	---	2.13	8.60	9.02	0.450	2.930	3.110	2.94	D
	3.5+4.2	3.91	4.69	---	---	2.13	8.60	9.11	0.450	2.920	3.160	2.95	D
	3.5+5.0	3.54	5.06	---	---	2.51	8.60	10.48	0.540	2.790	3.400	3.08	D
	3.5+6.0	3.17	5.43	---	---	2.69	8.60	10.59	0.550	2.420	3.000	3.55	B
	4.2+4.2	4.30	4.30	---	---	2.13	8.60	9.19	0.450	2.920	3.200	2.95	D
	4.2+5.0	3.93	4.67	---	---	2.51	8.60	10.49	0.540	2.790	3.470	3.08	D
	4.2+6.0	3.54	5.06	---	---	2.69	8.60	10.60	0.540	2.420	3.030	3.55	B
	5.0+5.0	4.30	4.30	---	---	2.88	8.60	10.67	0.630	2.700	3.380	3.19	D
	5.0+6.0	3.91	4.69	---	---	3.08	8.60	10.66	0.640	2.390	2.960	3.60	B
	2.0+2.0+2.0	2.63	2.63	2.63	---	1.97	7.89	10.04	0.440	2.050	2.700	3.85	A
	2.0+2.0+2.5	2.54	2.54	3.17	---	2.06	8.25	10.12	0.450	2.180	2.740	3.78	A
	2.0+2.0+3.5	2.29	2.29	4.02	---	2.26	8.60	10.22	0.470	2.340	2.880	3.68	A
	2.0+2.0+4.2	2.10	2.10	4.40	---	2.26	8.60	10.22	0.470	2.340	2.880	3.68	A
	2.0+2.0+5.0	1.91	1.91	4.78	---	2.66	8.60	10.40	0.580	2.340	2.960	3.68	A
	2.0+2.0+6.0	1.72	1.72	5.16	---	2.87	8.60	10.53	0.580	2.120	2.670	4.06	A
	2.0+2.5+2.5	2.46	3.07	3.07	---	2.16	8.60	10.13	0.460	2.350	2.840	3.66	A
	2.0+2.5+3.5	2.15	2.69	3.76	---	2.35	8.60	10.22	0.490	2.340	2.880	3.68	A
	2.0+2.5+4.2	1.98	2.47	4.15	---	2.36	8.60	10.23	0.490	2.340	2.870	3.68	A
	2.0+2.5+5.0	1.81	2.26	4.53	---	2.75	8.60	10.63	0.600	2.320	2.990	3.71	A
	2.0+2.5+6.0	1.64	2.05	4.91	---	2.96	8.60	10.64	0.600	2.100	2.640	4.10	A
	2.0+3.5+3.5	1.92	3.34	3.34	---	2.64	8.60	10.35	0.550	2.310	2.930	3.72	A
	2.0+3.5+4.2	1.77	3.10	3.72	---	2.64	8.60	10.35	0.550	2.310	2.920	3.72	A
	2.0+3.5+5.0	1.64	2.87	4.09	---	2.94	8.60	10.68	0.620	2.290	3.060	3.76	A
	2.0+4.2+4.2	1.65	3.47	3.47	---	2.64	8.60	10.36	0.550	2.310	2.920	3.72	A
	2.5+2.5+2.5	2.86	2.86	2.86	---	2.26	8.58	10.24	0.480	2.350	2.870	3.65	A
	2.5+2.5+3.5	2.53	2.53	3.54	---	2.45	8.60	10.45	0.510	2.340	2.960	3.68	A
	2.5+2.5+4.2	2.34	2.34	3.93	---	2.45	8.60	10.46	0.510	2.340	2.960	3.68	A
	2.5+2.5+5.0	2.15	2.15	4.30	---	2.85	8.60	10.64	0.620	2.290	3.020	3.76	A
	2.5+2.5+6.0	1.95	1.95	4.70	---	3.06	8.60	10.65	0.620	2.080	2.640	4.13	A
	2.5+3.5+3.5	2.26	3.17	3.17	---	2.73	8.60	10.58	0.560	2.310	2.960	3.72	A
	2.5+3.5+4.2	2.11	2.95	3.54	---	2.74	8.60	10.59	0.560	2.310	2.950	3.72	A
	2.5+3.5+5.0	1.95	2.74	3.91	---	3.13	8.60	10.65	0.640	2.290	2.980	3.76	A
	2.5+4.2+4.2	1.97	3.31	3.31	---	2.74	8.60	10.59	0.560	2.310	2.950	3.72	A
3.5+3.5+3.5	2.86	2.86	2.86	---	2.92	8.58	10.63	0.610	2.290	3.030	3.75	A	
2.0+2.0+2.0+2.0	2.15	2.15	2.15	2.15	2.42	8.60	10.39	0.520	1.910	2.610	4.50	A	
2.0+2.0+2.0+2.5	2.02	2.02	2.02	2.54	2.52	8.60	10.48	0.530	1.910	2.570	4.50	A	
2.0+2.0+2.0+3.5	1.81	1.81	1.81	3.17	2.72	8.60	10.58	0.570	1.900	2.630	4.53	A	
2.0+2.0+2.0+4.2	1.69	1.69	1.69	3.54	2.73	8.60	10.59	0.560	1.900	2.630	4.53	A	
2.0+2.0+2.0+5.0	1.56	1.56	1.56	3.92	3.04	8.60	10.65	0.630	1.860	2.540	4.62	A	
2.0+2.0+2.5+2.5	1.91	1.91	2.39	2.39	2.62	8.60	10.49	0.550	1.910	2.570	4.50	A	
2.0+2.0+2.5+3.5	1.72	1.72	2.15	3.01	2.92	8.60	10.59	0.600	1.900	2.630	4.53	A	
2.0+2.0+2.5+4.2	1.61	1.61	2.01	3.38	2.92	8.60	10.59	0.600	1.900	2.630	4.53	A	
2.0+2.0+3.5+3.5	1.56	1.56	2.74	2.74	3.12	8.60	10.69	0.650	1.900	2.660	4.53	A	
2.0+2.5+2.5+2.5	1.82	2.26	2.26	2.26	2.72	8.60	10.49	0.570	1.910	2.570	4.50	A	
2.0+2.5+2.5+3.5	1.64	2.05	2.05	2.86	3.02	8.60	10.68	0.630	1.900	2.670	4.53	A	
2.5+2.5+2.5+2.5	2.15	2.15	2.15	2.15	2.82	8.60	10.67	0.570	1.910	2.590	4.50	A	
2.5+2.5+2.5+3.5	1.95	1.95	1.95	2.75	3.12	8.60	10.68	0.640	1.810	2.580	4.75	A	

COOLING														
OUTDOOR UNIT	INDOOR UNIT	COOLING CAPACITY (kW)				TOTAL CAPACITY (kW)			POWER INPUT COOLING (kW)			EER	ENERGY LABEL	AEC (kWh)
		A ROOM	B ROOM	C ROOM	D ROOM	Min.	Nom.	Max.	Min.	Nom.	Max.			
	2.0	2.00	---	---	---	1.80	2.00	2.99	0.45	0.61	1.10	3.28	A	305
	2.5	2.50	---	---	---	1.87	2.50	3.52	0.49	0.78	1.33	3.21	A	390
	3.5	3.50	---	---	---	1.91	3.50	4.80	0.49	1.19	1.82	2.94	C	595
	4.2	4.20	---	---	---	1.99	4.20	5.26	0.53	1.52	1.92	2.76	D	760
	5.0	5.00	---	---	---	2.07	5.00	5.70	0.49	1.82	2.08	2.75	D	910
	6.0	6.00	---	---	---	2.17	6.00	6.60	0.50	1.99	2.38	3.02	B	995
	71	710	---	---	---	2.28	710	737	0.50	2.69	2.88	2.64	D	1,345
	2.0+2.0	2.00	2.00	---	---	1.97	4.00	5.30	0.50	1.23	1.67	3.25	A	615
	2.0+2.5	2.00	2.50	---	---	2.02	4.50	5.73	0.50	1.38	1.77	3.26	A	690
	2.0+3.5	2.00	3.50	---	---	2.12	5.50	6.31	0.50	1.77	2.44	3.11	B	885
	2.0+4.2	2.00	4.20	---	---	2.19	6.20	713	0.50	2.21	2.56	2.81	C	1,105
	2.0+5.0	2.00	5.00	---	---	2.27	7.00	730	0.51	2.51	2.76	2.79	D	1,255
	2.0+6.0	1.83	5.48	---	---	2.41	731	790	0.55	2.48	2.87	2.95	C	1,240
	2.0+71	1.66	5.90	---	---	2.56	756	8.45	0.59	2.67	3.29	2.83	C	1,335
	2.5+2.5	2.50	2.50	---	---	2.07	5.00	6.12	0.46	1.47	2.44	3.40	A	735
	2.5+3.5	2.50	3.50	---	---	2.17	6.00	6.60	0.50	1.99	2.38	3.02	B	995
	2.5+4.2	2.50	4.20	---	---	2.24	6.70	711	0.50	2.44	2.63	2.75	D	1,220
	2.5+5.0	2.40	4.79	---	---	2.34	719	759	0.54	2.64	2.96	2.72	D	1,320
	2.5+6.0	2.18	5.24	---	---	2.48	742	8.16	0.59	2.60	3.07	2.85	C	1,300
	2.5+71	2.00	5.68	---	---	2.63	768	8.66	0.59	2.74	3.43	2.80	D	1,370
	3.5+3.5	3.50	3.50	---	---	2.27	7.00	730	0.50	2.63	2.88	2.66	D	1,315
	3.5+4.2	3.29	3.95	---	---	2.37	724	773	0.54	2.82	3.08	2.57	E	1,410
	3.5+5.0	3.06	4.36	---	---	2.48	742	8.16	0.58	2.83	3.37	2.62	D	1,415
	3.5+6.0	2.82	4.83	---	---	2.61	765	8.62	0.59	2.74	4.11	2.79	D	1,370
	3.5+71	2.61	5.30	---	---	2.77	791	8.31	0.63	2.87	3.15	2.76	D	1,435
	4.2+4.2	3.70	3.70	---	---	2.46	740	8.11	0.58	2.88	3.42	2.57	E	1,440
	4.2+5.0	3.46	4.12	---	---	2.57	758	8.48	0.58	2.96	3.59	2.56	E	1,480
	4.2+6.0	3.22	4.60	---	---	2.71	782	8.89	0.63	2.80	3.66	2.79	D	1,400
	4.2+71	2.97	5.03	---	---	2.86	8.00	8.98	0.67	2.94	3.67	2.72	D	1,470
	5.0+5.0	3.88	3.88	---	---	2.68	776	8.66	0.62	2.98	3.62	2.60	E	1,490
	5.0+6.0	3.64	4.36	---	---	2.82	8.00	9.14	0.67	2.88	3.69	2.78	D	1,440
	5.0+71	3.31	4.69	---	---	2.97	8.00	9.35	0.67	2.82	3.85	2.84	C	1,410
	6.0+6.0	4.00	4.00	---	---	2.96	8.00	9.39	0.67	2.65	3.60	3.02	B	1,325
	6.0+71	3.66	4.34	---	---	3.11	8.00	9.55	0.71	2.58	3.76	3.10	B	1,290
	71+71	4.00	4.00	---	---	3.26	8.00	9.60	0.75	2.51	3.77	3.19	B	1,255
	2.0+2.0+2.0	2.00	2.00	2.00	---	2.17	6.00	6.63	0.52	1.73	2.12	3.47	A	865
	2.0+2.0+2.5	2.00	2.00	2.50	---	2.22	6.50	6.95	0.52	2.00	2.29	3.25	A	1,000
	2.0+2.0+3.5	1.92	1.92	3.35	---	2.34	719	761	0.55	2.42	2.67	2.97	C	1,210
	2.0+2.0+4.2	1.80	1.80	3.75	---	2.44	735	8.01	0.55	2.54	2.87	2.89	C	1,270
	2.0+2.0+5.0	1.68	1.68	4.18	---	2.55	754	8.40	0.59	2.55	3.17	2.96	C	1,275
	2.0+2.0+6.0	1.55	1.55	4.67	---	2.68	777	8.82	0.60	2.45	3.14	3.17	B	1,225
	2.0+2.0+71	1.44	1.44	5.12	---	2.83	8.00	9.18	0.64	2.58	3.45	3.10	B	1,290
	2.0+2.5+2.5	2.00	2.50	2.50	---	2.27	7.00	730	0.52	2.29	2.48	3.06	B	1,145
	2.0+2.5+3.5	1.83	2.28	3.20	---	2.41	731	790	0.55	2.48	2.87	2.95	C	1,240
	2.0+2.5+4.2	1.72	2.15	3.60	---	2.50	747	8.26	0.59	2.61	3.01	2.86	C	1,305
	2.0+2.5+5.0	1.61	2.01	4.03	---	2.61	765	8.62	0.59	2.62	3.31	2.92	C	1,310
	2.0+2.5+6.0	1.50	1.88	4.50	---	2.75	788	8.99	0.64	2.51	3.29	3.14	B	1,255
	2.0+2.5+71	1.38	1.72	4.90	---	2.90	8.00	9.30	0.67	2.58	3.53	3.10	B	1,290
	2.0+3.5+3.5	1.68	2.93	2.93	---	2.55	754	8.40	0.59	2.67	3.22	2.82	C	1,335

4MXS80E

COOLING														
OUTDOOR UNIT	INDOOR UNIT	COOLING CAPACITY (kW)				TOTAL CAPACITY (kW)			POWER INPUT COOLING (kW)			EER	ENERGY LABEL	AEC (kWh)
		A ROOM	B ROOM	C ROOM	D ROOM	Min.	Nom.	Max.	Min.	Nom.	Max.			
4MXS80E	2.0+3.5+4.2	1.59	2.78	3.33	---	2.64	7.70	8.70	0.63	2.74	3.37	2.81	C	1,370
	2.0+3.5+5.0	1.50	2.63	3.75	---	2.75	7.88	8.99	0.63	2.75	3.61	2.87	C	1,375
	2.0+3.5+6.0	1.39	2.43	4.18	---	2.89	8.00	9.28	0.67	2.58	3.52	3.10	B	1,290
	2.0+3.5+7.1	1.27	2.22	4.51	---	3.04	8.00	9.10	0.67	2.51	3.30	3.19	B	1,255
	2.0+4.2+4.2	1.52	3.17	3.17	---	2.74	7.86	8.99	0.63	2.74	3.66	2.87	C	1,370
	2.0+4.2+5.0	1.43	3.00	3.57	---	2.85	8.00	9.23	0.67	2.75	3.77	2.91	C	1,375
	2.0+4.2+6.0	1.32	2.75	3.93	---	2.98	8.00	9.45	0.67	2.51	3.60	3.19	B	1,255
	2.0+4.2+7.1	1.20	2.53	4.27	---	3.14	8.00	9.60	0.71	2.52	3.69	3.17	B	1,260
	2.0+5.0+5.0	1.34	3.33	3.33	---	2.96	8.00	9.39	0.67	2.76	3.80	2.90	C	1,380
	2.0+5.0+6.0	1.23	3.08	3.69	---	3.09	8.00	9.54	0.71	2.46	3.63	3.25	A	1,230
	2.0+5.0+7.1	1.13	2.84	4.03	---	3.25	8.00	9.60	0.71	2.39	3.63	3.35	A	1,195
	2.0+6.0+6.0	1.14	3.43	3.43	---	3.23	8.00	9.60	0.72	2.28	3.37	3.51	A	1,140
	2.5+2.5+2.5	2.40	2.40	2.40	---	2.34	7.20	7.61	0.55	2.42	2.67	2.98	C	1,210
	2.5+2.5+3.5	2.18	2.18	3.06	---	2.48	7.42	8.16	0.59	2.54	3.08	2.92	C	1,270
	2.5+2.5+4.2	2.06	2.06	3.46	---	2.57	7.58	8.49	0.59	2.67	3.29	2.84	C	1,335
	2.5+2.5+5.0	1.94	1.94	3.89	---	2.68	7.77	8.82	0.63	2.68	3.46	2.90	C	1,340
	2.5+2.5+6.0	1.82	1.82	4.36	---	2.82	8.00	9.15	0.64	2.58	3.45	3.10	B	1,290
	2.5+2.5+7.1	1.65	1.65	4.70	---	2.97	8.00	9.41	0.67	2.51	3.61	3.19	B	1,255
	2.5+3.5+3.5	2.01	2.82	2.82	---	2.61	7.65	8.34	0.59	2.74	3.01	2.79	D	1,370
	2.5+3.5+4.2	1.92	2.68	3.22	---	2.71	7.82	8.89	0.63	2.80	3.44	2.79	D	1,400
	2.5+3.5+5.0	1.81	2.55	3.64	---	2.82	8.00	9.15	0.67	2.82	3.69	2.84	C	1,410
	2.5+3.5+6.0	1.67	2.33	4.00	---	2.96	8.00	9.39	0.67	2.58	3.60	3.10	B	1,290
	2.5+3.5+7.1	1.52	2.14	4.34	---	3.11	8.00	9.10	0.71	2.51	3.30	3.19	B	1,255
	2.5+4.2+4.2	1.84	3.07	3.07	---	2.81	7.98	9.15	0.67	2.87	3.82	2.78	D	1,435
	2.5+4.2+5.0	1.71	2.87	3.42	---	2.92	8.00	9.35	0.67	2.82	3.85	2.84	C	1,410
	2.5+4.2+6.0	1.57	2.65	3.78	---	3.05	8.00	9.53	0.67	2.58	3.68	3.10	B	1,290
	2.5+4.2+7.1	1.45	2.43	4.12	---	3.20	8.00	9.63	0.71	2.52	3.77	3.17	B	1,260
	2.5+5.0+5.0	1.60	3.20	3.20	---	3.03	8.00	9.47	0.71	2.76	3.88	2.90	C	1,380
	2.5+5.0+6.0	1.48	2.96	3.56	---	3.16	8.00	9.58	0.71	2.46	3.63	3.25	A	1,230
	2.5+6.0+6.0	1.38	3.31	3.31	---	3.30	8.00	9.60	0.72	2.22	3.37	3.60	A	1,110
	3.5+3.5+3.5	2.63	2.63	2.63	---	2.75	7.89	8.67	0.63	2.87	3.15	2.75	D	1,435
	3.5+3.5+4.2	2.50	2.50	3.01	---	2.85	8.01	9.29	0.67	2.94	3.66	2.72	D	1,470
	3.5+3.5+5.0	2.33	2.33	3.34	---	2.96	8.00	9.35	0.67	2.82	3.85	2.84	C	1,410
	3.5+3.5+6.0	2.15	2.15	3.70	---	3.09	8.00	9.11	0.71	2.58	3.37	3.10	B	1,290
	3.5+3.5+7.1	1.99	1.99	4.02	---	3.25	8.00	9.60	0.75	2.52	3.77	3.17	B	1,260
	3.5+4.2+4.2	2.36	2.82	2.82	---	2.94	8.00	9.18	0.67	2.87	3.82	2.79	D	1,435
	3.5+4.2+5.0	2.21	2.65	3.14	---	3.05	8.00	9.36	0.71	2.75	3.85	2.91	C	1,375
	3.5+4.2+6.0	2.06	2.45	3.49	---	3.19	8.00	9.59	0.71	2.51	3.77	3.19	B	1,255
	3.5+5.0+5.0	2.08	2.96	2.96	---	3.16	8.00	9.55	0.71	2.76	3.88	2.90	C	1,380
	3.5+5.0+6.0	1.93	2.76	3.31	---	3.30	8.00	9.60	0.75	2.46	3.63	3.25	A	1,230
	4.2+4.2+4.2	2.67	2.67	2.67	---	3.04	8.00	9.19	0.71	2.87	3.82	2.79	D	1,435
	4.2+4.2+5.0	2.51	2.51	2.98	---	3.15	8.00	9.37	0.71	2.75	3.85	2.91	C	1,375
	4.2+4.2+6.0	2.33	2.33	3.34	---	3.29	8.00	9.60	0.75	2.51	3.77	3.19	B	1,255
	4.2+5.0+5.0	2.36	2.82	2.82	---	3.26	8.00	9.56	0.75	2.70	3.88	2.96	C	1,350
	2.0+2.0+2.0+2.0	1.83	1.83	1.83	1.83	2.41	7.32	7.90	0.56	2.07	2.38	3.54	A	1,035
	2.0+2.0+2.0+2.5	1.75	1.75	1.75	2.17	2.48	7.42	8.16	0.56	2.13	2.51	3.48	A	1,065
	2.0+2.0+2.0+3.5	1.61	1.61	1.61	2.82	2.61	7.65	8.62	0.60	2.26	2.86	3.38	A	1,130
	2.0+2.0+2.0+4.2	1.53	1.53	1.53	3.23	2.71	7.82	8.89	0.64	2.32	3.00	3.37	A	1,160
2.0+2.0+2.0+5.0	1.45	1.45	1.45	3.65	2.82	8.00	9.15	0.64	2.52	3.32	3.17	B	1,260	

COOLING														
OUTDOOR UNIT	INDOOR UNIT	COOLING CAPACITY (kW)				TOTAL CAPACITY (kW)			POWER INPUT COOLING (kW)			EER	ENERGY LABEL	AEC (kWh)
		A ROOM	B ROOM	C ROOM	D ROOM	Min.	Nom.	Max.	Min.	Nom.	Max.			
4MXS80E	20+20+20+60	1.33	1.33	1.33	4.01	2.96	8.00	9.39	0.68	2.28	3.21	3.51	A	1,140
	20+20+20+71	1.22	1.22	1.22	4.34	3.11	8.00	9.55	0.68	2.22	3.29	3.60	A	1,110
	20+20+25+25	1.68	1.68	2.09	2.09	2.55	7.54	8.40	0.60	2.20	2.72	3.43	A	1,100
	20+20+25+35	1.55	1.55	1.94	2.73	2.68	7.77	8.82	0.60	2.45	3.14	3.17	B	1,225
	20+20+25+42	1.48	1.48	1.85	3.12	2.78	7.93	9.06	0.64	2.58	3.30	3.07	B	1,290
	20+20+25+50	1.39	1.39	1.74	3.48	2.89	8.00	9.28	0.64	2.52	3.39	3.17	B	1,260
	20+20+25+60	1.28	1.28	1.60	3.84	3.03	8.00	9.47	0.68	2.28	3.21	3.51	A	1,140
	20+20+25+71	1.18	1.18	1.47	4.17	3.18	8.00	9.59	0.72	2.22	3.29	3.60	A	1,110
	20+20+35+35	1.45	1.45	2.55	2.55	2.82	8.00	8.96	0.64	2.58	3.22	3.10	B	1,290
	20+20+35+42	1.37	1.37	2.39	2.87	2.92	8.00	9.32	0.67	2.58	3.53	3.10	B	1,290
	20+20+35+50	1.28	1.28	2.24	3.20	3.03	8.00	9.47	0.68	2.52	3.55	3.17	B	1,260
	20+20+35+60	1.19	1.19	2.07	3.55	3.16	8.00	9.58	0.72	2.28	3.29	3.51	A	1,140
	20+20+42+42	1.29	1.29	2.71	2.71	3.01	8.00	9.46	0.67	2.58	3.61	3.10	B	1,290
	20+20+42+50	1.21	1.21	2.55	3.03	3.12	8.00	9.56	0.71	2.52	3.55	3.17	B	1,260
	20+20+42+60	1.13	1.13	2.37	3.37	3.26	8.00	9.60	0.72	2.28	3.29	3.51	A	1,140
	20+20+50+50	1.14	1.14	2.86	2.86	3.23	8.00	9.60	0.71	2.44	3.50	3.28	A	1,220
	20+25+25+25	1.62	2.01	2.01	2.01	2.61	7.65	8.62	0.60	2.26	2.85	3.38	A	1,130
	20+25+25+35	1.50	1.88	1.88	2.62	2.75	7.88	8.99	0.64	2.51	3.29	3.14	B	1,255
	20+25+25+42	1.43	1.79	1.79	2.99	2.85	8.00	9.20	0.64	2.58	3.45	3.10	B	1,290
	20+25+25+50	1.33	1.67	1.67	3.33	2.96	8.00	9.39	0.68	2.52	3.47	3.17	B	1,260
	20+25+25+60	1.23	1.54	1.54	3.69	3.09	8.00	9.54	0.68	2.25	3.29	3.56	A	1,125
	20+25+25+71	1.13	1.42	1.42	4.03	3.25	8.00	9.60	0.72	2.28	3.29	3.51	A	1,140
	20+25+35+35	1.40	1.74	2.43	2.43	2.89	8.00	9.14	0.67	2.58	3.37	3.10	B	1,290
	20+25+35+42	1.31	1.64	2.30	2.75	2.98	8.00	9.47	0.67	2.58	3.61	3.10	B	1,290
	20+25+35+50	1.23	1.54	2.15	3.08	3.09	8.00	9.54	0.71	2.52	3.55	3.17	B	1,260
	20+25+35+60	1.14	1.43	2.00	3.43	3.23	8.00	9.60	0.72	2.28	3.29	3.51	A	1,140
	20+25+42+42	1.25	1.55	2.60	2.60	3.08	8.00	9.53	0.71	2.58	3.69	3.10	B	1,290
	20+25+42+50	1.17	1.46	2.45	2.92	3.19	8.00	9.59	0.71	2.52	3.63	3.17	B	1,260
	20+25+42+60	1.10	1.38	2.76	2.76	3.30	8.00	9.60	0.71	2.40	3.50	3.33	A	1,200
	20+35+35+35	1.28	2.24	2.24	2.24	3.03	8.00	9.23	0.67	2.58	3.30	3.10	B	1,290
	20+35+35+42	1.21	2.12	2.12	2.55	3.12	8.00	9.56	0.71	2.58	3.69	3.10	B	1,290
	20+35+35+50	1.14	2.00	2.00	2.86	3.23	8.00	9.60	0.71	2.52	3.63	3.17	B	1,260
	20+35+42+42	1.15	2.01	2.42	2.42	3.22	8.00	9.60	0.71	2.58	3.77	3.10	B	1,290
	25+25+25+25	1.94	1.94	1.94	1.94	2.68	7.76	8.82	0.60	2.45	3.14	3.17	B	1,225
	25+25+25+35	1.82	1.82	1.82	2.54	2.82	8.00	8.98	0.64	2.58	3.22	3.10	B	1,290
	25+25+25+42	1.71	1.71	1.71	2.87	2.92	8.00	9.32	0.67	2.58	3.53	3.10	B	1,290
	25+25+25+50	1.60	1.60	1.60	3.20	3.03	8.00	9.47	0.68	2.52	3.55	3.17	B	1,260
	25+25+25+60	1.48	1.48	1.48	3.56	3.16	8.00	9.58	0.72	2.28	3.29	3.51	A	1,140
	25+25+35+35	1.67	1.67	2.33	2.33	2.96	8.00	9.10	0.67	2.58	3.37	3.10	B	1,290
	25+25+35+42	1.57	1.57	2.21	2.65	3.05	8.00	9.50	0.67	2.58	3.69	3.10	B	1,290
	25+25+35+50	1.48	1.48	2.07	2.97	3.16	8.00	9.58	0.71	2.52	3.63	3.17	B	1,260
	25+25+35+60	1.38	1.38	1.93	3.31	3.30	8.00	9.60	0.72	2.28	3.29	3.51	A	1,140
	25+25+42+42	1.49	1.49	2.51	2.51	3.15	8.00	9.57	0.71	2.58	3.69	3.10	B	1,290
	25+25+42+50	1.41	1.41	2.37	2.81	3.26	8.00	9.60	0.71	2.52	3.63	3.17	B	1,260
	25+35+35+35	1.55	2.15	2.15	2.15	3.09	8.00	9.35	0.71	2.58	3.30	3.10	B	1,290
	25+35+35+42	1.47	2.04	2.04	2.45	3.19	8.00	9.59	0.71	2.58	3.77	3.10	B	1,290
	25+35+35+50	1.38	1.93	1.93	2.76	3.30	8.00	9.60	0.75	2.52	3.63	3.17	B	1,260
	25+35+42+42	1.40	1.94	2.33	2.33	3.29	8.00	9.60	0.75	2.58	3.77	3.10	B	1,290
35+35+35+35	2.00	2.00	2.00	2.00	3.23	8.00	9.60	0.71	2.58	3.77	3.10	B	1,290	

HEATING													
OUTDOOR UNIT	INDOOR UNIT	HEATING CAPACITY (kW)				TOTAL CAPACITY (kW)			POWER INPUT HEATING (kW)			COP	ENERGY LABEL
		A ROOM	B ROOM	C ROOM	D ROOM	Min.	Nom.	Max.	Min.	Nom.	Max.		
4MXS80E	2.0	2.44	---	---	---	1.31	2.44	4.10	0.31	0.67	1.22	3.64	A
	2.5	3.05	---	---	---	1.36	3.05	4.55	0.33	0.88	1.31	3.47	B
	3.5	4.27	---	---	---	1.48	4.27	5.11	0.34	1.42	1.73	3.01	D
	4.2	5.12	---	---	---	1.68	5.12	5.17	0.37	1.73	1.77	2.96	D
	5.0	6.09	---	---	---	1.90	6.09	7.12	0.44	1.78	2.25	3.42	B
	6.0	7.31	---	---	---	2.19	7.31	8.19	0.55	2.19	2.64	3.34	C
	7.1	8.65	---	---	---	2.50	8.65	9.00	0.59	2.77	2.97	3.12	D
	2.0+2.0	2.44	2.44	---	---	1.62	4.88	6.55	0.34	1.17	1.74	4.17	A
	2.0+2.5	2.44	3.05	---	---	1.76	5.49	6.85	0.37	1.34	1.82	4.10	A
	2.0+3.5	2.44	4.26	---	---	2.05	6.70	7.35	0.43	1.86	2.13	3.60	A
	2.0+4.2	2.44	5.11	---	---	2.24	7.55	7.35	0.47	2.22	2.13	3.40	C
	2.0+5.0	2.44	6.09	---	---	2.47	8.53	8.72	0.55	2.32	2.42	3.68	A
	2.0+6.0	2.32	6.95	---	---	2.74	9.27	9.67	0.57	2.44	2.64	3.80	A
	2.0+7.1	2.11	7.49	---	---	3.04	9.60	10.36	0.61	2.48	2.89	3.87	A
	2.5+2.5	3.04	3.04	---	---	1.90	6.08	7.16	0.41	1.69	2.14	3.60	B
	2.5+3.5	3.05	4.26	---	---	2.19	7.31	8.53	0.55	2.13	2.67	3.43	B
	2.5+4.2	3.04	5.12	---	---	2.39	8.16	8.53	0.57	2.46	2.67	3.32	C
	2.5+5.0	2.98	5.95	---	---	2.61	8.93	9.31	0.57	2.52	2.72	3.54	B
	2.5+6.0	2.82	6.78	---	---	2.88	9.60	10.10	0.59	2.65	2.94	3.62	A
	2.5+7.1	2.50	7.10	---	---	3.17	9.60	10.36	0.63	2.51	2.93	3.82	A
	3.5+3.5	4.26	4.26	---	---	2.47	8.52	9.18	0.59	2.70	3.04	3.16	D
	3.5+4.2	4.11	4.94	---	---	2.66	9.05	9.18	0.61	2.98	3.04	3.04	D
	3.5+5.0	3.95	5.65	---	---	2.88	9.60	9.92	0.62	2.77	2.93	3.47	B
	3.5+6.0	3.54	6.06	---	---	3.15	9.60	10.34	0.61	2.49	2.90	3.86	A
	3.5+7.1	3.17	6.43	---	---	3.45	9.60	10.37	0.67	2.43	2.84	3.95	A
	4.2+4.2	4.78	4.78	---	---	2.85	9.55	9.99	0.63	2.65	2.91	3.60	B
	4.2+5.0	4.38	5.22	---	---	3.07	9.60	10.12	0.64	2.61	2.87	3.68	A
	4.2+6.0	3.95	5.65	---	---	3.34	9.60	10.35	0.65	2.44	2.84	3.93	A
	4.2+7.1	3.57	6.03	---	---	3.63	9.60	10.38	0.70	2.43	2.83	3.95	A
	5.0+5.0	4.80	4.80	---	---	3.28	9.60	10.24	0.67	2.52	2.83	3.81	A
	5.0+6.0	4.36	5.24	---	---	3.55	9.60	10.47	0.66	2.40	2.80	4.00	A
	5.0+7.1	3.97	5.63	---	---	3.85	9.60	10.50	0.70	2.38	2.79	4.03	A
	6.0+6.0	4.80	4.80	---	---	3.82	9.60	10.70	0.67	2.32	2.77	4.14	A
	6.0+7.1	4.40	5.20	---	---	4.12	9.60	10.73	0.71	2.31	2.76	4.16	A
	7.1+7.1	4.80	4.80	---	---	4.42	9.60	10.77	0.78	2.25	2.70	4.27	A
	2.0+2.0+2.0	2.43	2.43	2.43	---	2.19	7.29	8.33	0.48	1.76	2.14	4.14	A
	2.0+2.0+2.5	2.44	2.44	3.04	---	2.33	7.92	8.93	0.50	1.96	2.32	4.04	A
	2.0+2.0+3.5	2.38	2.38	4.17	---	2.61	8.93	9.68	0.54	2.29	2.63	3.90	A
	2.0+2.0+4.2	2.30	2.30	4.81	---	2.80	9.41	9.69	0.56	2.48	2.63	3.79	A
	2.0+2.0+5.0	2.13	2.13	5.34	---	3.01	9.60	10.48	0.57	2.39	2.80	4.02	A
	2.0+2.0+6.0	1.92	1.92	5.76	---	3.28	9.60	10.71	0.58	2.27	2.72	4.23	A
	2.0+2.0+7.1	1.73	1.73	6.14	---	3.58	9.60	10.74	0.62	2.26	2.71	4.25	A
	2.0+2.5+2.5	2.43	3.05	3.05	---	2.47	8.53	8.93	0.52	2.16	2.30	3.95	A
	2.0+2.5+3.5	2.31	2.90	4.06	---	2.74	9.27	9.68	0.56	2.41	2.61	3.85	A
	2.0+2.5+4.2	2.21	2.76	4.63	---	2.93	9.60	9.69	0.59	2.56	2.61	3.75	A
	2.0+2.5+5.0	2.02	2.53	5.05	---	3.15	9.60	10.48	0.59	2.39	2.80	4.02	A
	2.0+2.5+6.0	1.82	2.29	5.49	---	3.42	9.60	10.71	0.60	2.27	2.72	4.23	A
	2.0+2.5+7.1	1.65	2.07	5.88	---	3.72	9.60	10.74	0.64	2.26	2.71	4.25	A
	2.0+3.5+3.5	2.14	3.73	3.73	---	3.01	9.60	10.35	0.59	2.43	2.84	3.95	A

HEATING													
OUTDOOR UNIT	INDOOR UNIT	HEATING CAPACITY (kW)				TOTAL CAPACITY (kW)			POWER INPUT HEATING (kW)			COP	ENERGY LABEL
		A ROOM	B ROOM	C ROOM	D ROOM	Min.	Nom.	Max.	Min.	Nom.	Max.		
4MXS80E	2.0+3.5+4.2	1.99	3.46	4.15	---	3.20	9.60	10.36	0.63	2.43	2.84	3.95	A
	2.0+3.5+5.0	1.83	3.20	4.57	---	3.42	9.60	10.49	0.63	2.39	2.80	4.02	A
	2.0+3.5+6.0	1.67	2.92	5.01	---	3.69	9.60	10.72	0.64	2.27	2.72	4.23	A
	2.0+3.5+7.1	1.52	2.67	5.41	---	3.99	9.60	10.75	0.69	2.26	2.70	4.25	A
	2.0+4.2+4.2	1.84	3.88	3.88	---	3.39	9.60	10.37	0.65	2.43	2.84	3.95	A
	2.0+4.2+5.0	1.71	3.60	4.29	---	3.61	9.60	10.49	0.68	2.39	2.79	4.02	A
	2.0+4.2+6.0	1.58	3.30	4.72	---	3.88	9.60	10.72	0.67	2.27	2.71	4.23	A
	2.0+4.2+7.1	1.45	3.03	5.12	---	4.18	9.60	10.76	0.73	2.26	2.70	4.25	A
	2.0+5.0+5.0	1.60	4.00	4.00	---	3.82	9.60	10.62	0.68	2.30	2.75	4.17	A
	2.0+5.0+6.0	1.48	3.69	4.43	---	4.09	9.60	10.85	0.69	2.18	2.72	4.40	A
	2.0+5.0+7.1	1.37	3.40	4.83	---	4.39	9.60	10.88	0.74	2.17	2.71	4.42	A
	2.0+6.0+6.0	1.38	4.11	4.11	---	4.36	9.60	11.08	0.70	2.11	2.64	4.55	A
	2.5+2.5+2.5	2.97	2.97	2.97	---	2.61	8.91	9.88	0.54	2.34	2.74	3.81	A
	2.5+2.5+3.5	2.82	2.82	3.96	---	2.88	9.60	10.12	0.59	2.53	2.79	3.79	A
	2.5+2.5+4.2	2.61	2.61	4.38	---	3.07	9.60	10.12	0.61	2.53	2.79	3.79	A
	2.5+2.5+5.0	2.40	2.40	4.80	---	3.28	9.60	10.48	0.61	2.39	2.80	4.02	A
	2.5+2.5+6.0	2.18	2.18	5.24	---	3.55	9.60	10.71	0.62	2.27	2.72	4.23	A
	2.5+2.5+7.1	1.98	1.98	5.64	---	3.85	9.60	10.74	0.66	2.26	2.71	4.25	A
	2.5+3.5+3.5	2.52	3.54	3.54	---	3.15	9.60	10.35	0.61	2.43	2.84	3.95	A
	2.5+3.5+4.2	2.36	3.29	3.95	---	3.34	9.60	10.36	0.65	2.43	2.84	3.95	A
	2.5+3.5+5.0	2.19	3.05	4.36	---	3.55	9.60	10.49	0.66	2.39	2.80	4.02	A
	2.5+3.5+6.0	2.00	2.80	4.80	---	3.82	9.60	10.72	0.67	2.27	2.72	4.23	A
	2.5+3.5+7.1	1.84	2.56	5.20	---	4.12	9.60	10.75	0.71	2.26	2.70	4.25	A
	2.5+4.2+4.2	2.20	3.70	3.70	---	3.53	9.60	10.37	0.68	2.43	2.84	3.95	A
	2.5+4.2+5.0	2.06	3.45	4.09	---	3.74	9.60	10.49	0.70	2.39	2.79	4.02	A
	2.5+4.2+6.0	1.90	3.17	4.53	---	4.01	9.60	10.72	0.69	2.27	2.71	4.23	A
	2.5+4.2+7.1	1.75	2.92	4.93	---	4.31	9.60	10.76	0.76	2.26	2.70	4.25	A
	2.5+5.0+5.0	1.92	3.84	3.84	---	3.96	9.60	10.62	0.71	2.30	2.75	4.17	A
	2.5+5.0+6.0	1.77	3.56	4.27	---	4.23	9.60	10.85	0.72	2.18	2.72	4.40	A
	2.5+6.0+6.0	1.66	3.97	3.97	---	4.50	9.60	11.08	0.72	2.11	2.64	4.55	A
	3.5+3.5+3.5	3.20	3.20	3.20	---	3.42	9.60	10.36	0.65	2.43	2.84	3.95	A
	3.5+3.5+4.2	3.00	3.00	3.60	---	3.61	9.60	10.37	0.70	2.43	2.84	3.95	A
	3.5+3.5+5.0	2.80	2.80	4.00	---	3.82	9.60	10.49	0.70	2.39	2.79	4.02	A
	3.5+3.5+6.0	2.58	2.58	4.44	---	4.09	9.60	10.72	0.71	2.27	2.71	4.23	A
	3.5+3.5+7.1	2.38	2.38	4.84	---	4.39	9.60	10.76	0.76	2.26	2.70	4.25	A
	3.5+4.2+4.2	2.82	3.39	3.39	---	3.80	9.60	10.38	0.72	2.43	2.83	3.95	A
	3.5+4.2+5.0	2.65	3.17	3.78	---	4.01	9.60	10.50	0.75	2.39	2.79	4.02	A
	3.5+4.2+6.0	2.45	2.94	4.21	---	4.28	9.60	10.73	0.74	2.26	2.71	4.25	A
	3.5+5.0+5.0	2.48	3.56	3.56	---	4.23	9.60	10.63	0.76	2.30	2.75	4.17	A
	3.5+5.0+6.0	2.32	3.31	3.97	---	4.50	9.60	10.86	0.77	2.18	2.72	4.40	A
	4.2+4.2+4.2	3.20	3.20	3.20	---	3.99	9.60	10.38	0.75	2.42	2.83	3.97	A
	4.2+4.2+5.0	3.01	3.01	3.58	---	4.20	9.60	10.51	0.78	2.38	2.79	4.03	A
	4.2+4.2+6.0	2.80	2.80	4.00	---	4.47	9.60	10.74	0.79	2.26	2.71	4.25	A
	4.2+5.0+5.0	2.84	3.38	3.38	---	4.42	9.60	10.64	0.81	2.29	2.74	4.19	A
	2.0+2.0+2.0+2.0	2.32	2.32	2.32	2.32	2.74	9.28	9.78	0.48	2.27	2.51	4.09	A
	2.0+2.0+2.0+2.5	2.26	2.26	2.26	2.82	2.88	9.60	9.92	0.52	2.36	2.51	4.07	A
	2.0+2.0+2.0+3.5	2.02	2.02	2.02	3.54	3.15	9.60	10.72	0.56	2.27	2.71	4.23	A
	2.0+2.0+2.0+4.2	1.88	1.88	1.88	3.96	3.34	9.60	10.73	0.58	2.26	2.71	4.25	A
2.0+2.0+2.0+5.0	1.75	1.75	1.75	4.35	3.55	9.60	10.86	0.60	2.18	2.72	4.40	A	

HEATING													
OUTDOOR UNIT	INDOOR UNIT	HEATING CAPACITY (kW)				TOTAL CAPACITY (kW)			POWER INPUT HEATING (kW)			COP	ENERGY LABEL
		A ROOM	B ROOM	C ROOM	D ROOM	Min.	Nom.	Max.	Min.	Nom.	Max.		
4MXS80E	2.0+2.0+2.0+6.0	1.60	1.60	1.60	4.80	3.82	9.60	11.09	0.59	2.10	2.64	4.57	A
	2.0+2.0+2.0+7.1	1.47	1.47	1.47	5.19	4.12	9.60	11.12	0.65	2.09	2.63	4.59	A
	2.0+2.0+2.5+2.5	2.13	2.13	2.67	2.67	3.01	9.60	10.71	0.54	2.27	2.72	4.23	A
	2.0+2.0+2.5+3.5	1.92	1.92	2.40	3.36	3.28	9.60	10.72	0.58	2.27	2.71	4.23	A
	2.0+2.0+2.5+4.2	1.79	1.79	2.25	3.77	3.47	9.60	10.73	0.60	2.26	2.71	4.25	A
	2.0+2.0+2.5+5.0	1.67	1.67	2.09	4.17	3.69	9.60	10.86	0.62	2.18	2.72	4.40	A
	2.0+2.0+2.5+6.0	1.54	1.54	1.92	4.60	3.96	9.60	11.09	0.61	2.10	2.64	4.57	A
	2.0+2.0+2.5+7.1	1.41	1.41	1.76	5.02	4.26	9.60	11.12	0.67	2.09	2.63	4.59	A
	2.0+2.0+3.5+3.5	1.75	1.75	3.05	3.05	3.55	9.60	10.73	0.62	2.26	2.71	4.25	A
	2.0+2.0+3.5+4.2	1.64	1.64	2.87	3.45	3.74	9.60	10.74	0.64	2.26	2.71	4.25	A
	2.0+2.0+3.5+5.0	1.54	1.54	2.69	3.83	3.96	9.60	10.86	0.67	2.17	2.71	4.42	A
	2.0+2.0+3.5+6.0	1.42	1.42	2.49	4.27	4.23	9.60	11.09	0.67	2.10	2.63	4.57	A
	2.0+2.0+4.2+4.2	1.55	1.55	3.25	3.25	3.93	9.60	10.75	0.66	2.26	2.70	4.25	A
	2.0+2.0+4.2+5.0	1.45	1.45	3.06	3.64	4.15	9.60	10.87	0.69	2.17	2.71	4.42	A
	2.0+2.0+4.2+6.0	1.35	1.35	2.84	4.06	4.42	9.60	11.10	0.70	2.10	2.63	4.57	A
	2.0+2.0+5.0+5.0	1.37	1.37	3.43	3.43	4.36	9.60	11.00	0.72	2.13	2.67	4.51	A
	2.0+2.5+2.5+2.5	2.01	2.53	2.53	2.53	3.15	9.60	10.71	0.56	2.27	2.72	4.23	A
	2.0+2.5+2.5+3.5	1.82	2.29	2.29	3.20	3.42	9.60	10.72	0.60	2.27	2.71	4.23	A
	2.0+2.5+2.5+4.2	1.72	2.14	2.14	3.60	3.61	9.60	10.73	0.62	2.26	2.71	4.25	A
	2.0+2.5+2.5+5.0	1.60	2.00	2.00	4.00	3.82	9.60	10.86	0.65	2.18	2.72	4.40	A
	2.0+2.5+2.5+6.0	1.47	1.85	1.85	4.43	4.09	9.60	11.09	0.65	2.10	2.64	4.57	A
	2.0+2.5+2.5+7.1	1.37	1.70	1.70	4.83	4.39	9.60	11.12	0.69	2.09	2.63	4.59	A
	2.0+2.5+3.5+3.5	1.67	2.09	2.92	2.92	3.69	9.60	10.73	0.64	2.26	2.71	4.25	A
	2.0+2.5+3.5+4.2	1.58	1.97	2.75	3.30	3.88	9.60	10.74	0.66	2.26	2.71	4.25	A
	2.0+2.5+3.5+5.0	1.48	1.85	2.58	3.69	4.09	9.60	10.86	0.69	2.18	2.71	4.40	A
	2.0+2.5+3.5+6.0	1.38	1.71	2.40	4.11	4.36	9.60	11.09	0.70	2.10	2.63	4.57	A
	2.0+2.5+4.2+4.2	1.50	1.86	3.12	3.12	4.07	9.60	10.75	0.69	2.26	2.70	4.25	A
	2.0+2.5+4.2+5.0	1.41	1.75	2.94	3.50	4.28	9.60	10.87	0.71	2.17	2.71	4.42	A
	2.0+2.5+5.0+5.0	1.32	1.66	3.31	3.31	4.50	9.60	11.00	0.74	2.13	2.67	4.51	A
	2.0+3.5+3.5+3.5	1.53	2.69	2.69	2.69	3.96	9.60	10.74	0.69	2.26	2.71	4.25	A
	2.0+3.5+3.5+4.2	1.45	2.55	2.55	3.05	4.15	9.60	10.75	0.71	2.26	2.70	4.25	A
	2.0+3.5+3.5+5.0	1.37	2.40	2.40	3.43	4.36	9.60	10.87	0.74	2.17	2.71	4.42	A
	2.0+3.5+4.2+4.2	1.38	2.42	2.90	2.90	4.34	9.60	10.75	0.76	2.26	2.70	4.25	A
	2.5+2.5+2.5+2.5	2.40	2.40	2.40	2.40	3.28	9.60	10.71	0.58	2.27	2.72	4.23	A
	2.5+2.5+2.5+3.5	2.18	2.18	2.18	3.06	3.55	9.60	10.72	0.62	2.27	2.71	4.23	A
	2.5+2.5+2.5+4.2	2.05	2.05	2.05	3.45	3.74	9.60	10.73	0.64	2.26	2.71	4.25	A
	2.5+2.5+2.5+5.0	1.92	1.92	1.92	3.84	3.96	9.60	10.86	0.67	2.18	2.72	4.40	A
	2.5+2.5+2.5+6.0	1.78	1.78	1.78	4.26	4.23	9.60	11.09	0.68	2.10	2.64	4.57	A
	2.5+2.5+3.5+3.5	2.00	2.00	2.80	2.80	3.82	9.60	10.73	0.67	2.26	2.71	4.25	A
	2.5+2.5+3.5+4.2	1.89	1.89	2.65	3.17	4.01	9.60	10.74	0.69	2.26	2.71	4.25	A
	2.5+2.5+3.5+5.0	1.78	1.78	2.49	3.55	4.23	9.60	10.86	0.71	2.18	2.71	4.40	A
	2.5+2.5+3.5+6.0	1.66	1.66	2.32	3.96	4.50	9.60	11.09	0.72	2.10	2.63	4.57	A
2.5+2.5+4.2+4.2	1.79	1.79	3.01	3.01	4.20	9.60	10.75	0.71	2.26	2.70	4.25	A	
2.5+2.5+4.2+5.0	1.69	1.69	2.85	3.37	4.42	9.60	10.87	0.76	2.17	2.71	4.42	A	
2.5+3.5+3.5+3.5	1.86	2.58	2.58	2.58	4.09	9.60	10.74	0.71	2.26	2.71	4.25	A	
2.5+3.5+3.5+4.2	1.76	2.45	2.45	2.94	4.28	9.60	10.75	0.74	2.26	2.70	4.25	A	
2.5+3.5+3.5+5.0	1.65	2.32	2.32	3.31	4.50	9.60	10.87	0.76	2.17	2.71	4.42	A	
2.5+3.5+4.2+4.2	1.67	2.33	2.80	2.80	4.47	9.60	10.75	0.78	2.26	2.70	4.25	A	
3.5+3.5+3.5+3.5	2.40	2.40	2.40	2.40	4.36	9.60	10.75	0.76	2.26	2.70	4.25	A	

COOLING															
OUTDOOR UNIT	INDOOR UNIT	COOLING CAPACITY (kW)					TOTAL CAPACITY (kW)			POWER INPUT COOLING (kW)			EER	ENERGY LABEL	AEC (kWh)
		A ROOM	B ROOM	C ROOM	D ROOM	E ROOM	Min.	Nom.	Max.	Min.	Nom.	Max.			
5MXS90E	2.0	2.00	---	---	---	---	1.88	2.00	3.03	0.45	0.56	1.02	3.57	A	280
	2.5	2.50	---	---	---	---	2.00	2.50	3.54	0.49	0.71	1.18	3.52	A	355
	3.5	3.50	---	---	---	---	2.05	3.50	4.82	0.52	1.14	1.47	3.07	B	570
	4.2	4.20	---	---	---	---	2.13	4.20	5.14	0.56	1.38	1.69	3.04	B	690
	5.0	5.00	---	---	---	---	2.22	5.00	5.50	0.49	1.64	1.83	3.05	B	820
	6.0	6.00	---	---	---	---	2.33	6.00	6.60	0.50	1.89	2.24	3.17	B	945
	7.1	7.10	---	---	---	---	2.45	7.10	7.38	0.53	2.57	2.74	2.76	D	1,285
	2.0+2.0	2.00	2.00	---	---	---	2.11	4.00	5.30	0.50	1.14	1.79	3.51	A	570
	2.0+2.5	2.00	2.50	---	---	---	2.16	4.50	5.73	0.50	1.30	1.79	3.46	A	650
	2.0+3.5	2.00	3.50	---	---	---	2.27	5.50	6.36	0.50	1.70	2.09	3.24	A	850
	2.0+4.2	2.00	4.20	---	---	---	2.35	6.20	6.75	0.50	1.99	2.35	3.12	B	995
	2.0+5.0	2.00	5.00	---	---	---	2.44	7.00	7.31	0.50	2.42	2.59	2.89	C	1,210
	2.0+6.0	1.86	5.56	---	---	---	2.58	7.42	7.96	0.54	2.45	2.81	3.03	B	1,225
	2.0+7.1	1.71	6.09	---	---	---	2.74	7.80	8.47	0.57	2.69	3.13	2.90	C	1,345
	2.5+2.5	2.50	2.50	---	---	---	2.22	5.00	6.20	0.46	1.39	1.99	3.60	A	695
	2.5+3.5	2.50	3.50	---	---	---	2.33	6.00	6.60	0.50	1.89	2.25	3.17	B	945
	2.5+4.2	2.50	4.20	---	---	---	2.41	6.70	7.11	0.50	2.30	2.57	2.91	C	1,150
	2.5+5.0	2.41	4.83	---	---	---	2.51	7.24	7.64	0.53	2.59	2.82	2.80	D	1,295
	2.5+6.0	2.23	5.36	---	---	---	2.66	7.59	8.25	0.57	2.57	3.00	2.95	C	1,285
	2.5+7.1	2.08	5.90	---	---	---	2.82	7.98	8.47	0.60	2.81	3.13	2.84	C	1,405
	3.5+3.5	3.50	3.50	---	---	---	2.44	7.00	7.31	0.53	2.52	2.69	2.78	D	1,260
	3.5+4.2	3.32	3.99	---	---	---	2.54	7.31	7.66	0.53	2.69	2.92	2.72	D	1,345
	3.5+5.0	3.13	4.46	---	---	---	2.66	7.59	7.83	0.57	2.82	2.94	2.69	D	1,410
	3.5+6.0	2.93	5.01	---	---	---	2.80	7.94	8.45	0.60	2.81	3.13	2.83	C	1,405
	3.5+7.1	2.75	5.58	---	---	---	2.96	8.33	8.47	0.64	3.07	3.13	2.71	D	1,535
	4.2+4.2	3.78	3.78	---	---	---	2.64	7.56	7.67	0.56	2.86	2.92	2.64	D	1,430
	4.2+5.0	3.58	4.26	---	---	---	2.76	7.84	8.01	0.60	2.94	3.07	2.67	D	1,470
	4.2+6.0	3.37	4.82	---	---	---	2.91	8.19	8.46	0.60	2.94	3.13	2.79	D	1,470
	4.2+7.1	3.19	5.39	---	---	---	3.07	8.58	8.66	0.64	3.26	3.26	2.63	D	1,630
	5.0+5.0	4.06	4.06	---	---	---	2.88	8.12	8.18	0.60	3.09	3.19	2.63	D	1,545
	5.0+6.0	3.85	4.62	---	---	---	3.02	8.47	8.64	0.64	3.09	3.25	2.74	D	1,545
	5.0+7.1	3.66	5.20	---	---	---	3.19	8.86	8.88	0.67	3.36	3.39	2.64	D	1,680
	6.0+6.0	4.41	4.41	---	---	---	3.17	8.82	9.27	0.64	3.08	3.36	2.86	C	1,540
	6.0+7.1	4.12	4.88	---	---	---	3.33	9.00	9.29	0.68	3.08	3.36	2.92	C	1,540
	7.1+7.1	4.50	4.50	---	---	---	3.49	9.00	9.31	0.71	3.02	3.36	2.98	C	1,510
	2.0+2.0+2.0	2.00	2.00	2.00	---	---	2.33	6.00	6.63	0.50	1.66	1.96	3.61	A	830
	2.0+2.0+2.5	2.00	2.00	2.50	---	---	2.38	6.50	6.97	0.50	1.91	2.17	3.40	A	955
	2.0+2.0+3.5	1.93	1.93	3.38	---	---	2.51	7.24	7.64	0.54	2.34	2.57	3.09	B	1,170
	2.0+2.0+4.2	1.83	1.83	3.83	---	---	2.61	7.49	8.08	0.54	2.45	2.88	3.06	B	1,225
	2.0+2.0+5.0	1.72	1.72	4.33	---	---	2.73	7.77	8.53	0.57	2.59	3.09	3.00	C	1,295
	2.0+2.0+6.0	1.62	1.62	4.88	---	---	2.88	8.12	9.03	0.58	2.56	3.22	3.17	B	1,280
	2.0+2.0+7.1	1.53	1.53	5.45	---	---	3.04	8.51	9.30	0.61	2.82	3.36	3.02	B	1,410
	2.0+2.5+2.5	2.00	2.50	2.50	---	---	2.44	7.00	7.31	0.50	2.17	2.40	3.23	A	1,085
	2.0+2.5+3.5	1.86	2.32	3.24	---	---	2.58	7.42	7.96	0.54	2.45	2.81	3.03	B	1,225
	2.0+2.5+4.2	1.76	2.20	3.70	---	---	2.69	7.66	8.36	0.57	2.57	3.07	2.98	C	1,285
	2.0+2.5+5.0	1.67	2.09	4.18	---	---	2.80	7.94	8.65	0.57	2.71	3.15	2.93	C	1,355
	2.0+2.5+6.0	1.58	1.98	4.74	---	---	2.95	8.30	9.10	0.61	2.69	3.22	3.09	B	1,345
	2.0+2.5+7.1	1.50	1.87	5.31	---	---	3.11	8.68	9.30	0.64	2.95	3.36	2.94	C	1,475

COOLING															
OUTDOOR UNIT	INDOOR UNIT	COOLING CAPACITY (kW)					TOTAL CAPACITY (kW)			POWER INPUT COOLING (kW)			EER	ENERGY LABEL	AEC (kWh)
		A ROOM	B ROOM	C ROOM	D ROOM	E ROOM	Min.	Nom.	Max.	Min.	Nom.	Max.			
5MXS90E	2.0+3.5+3.5	1.73	3.02	3.02	---	---	2.73	7.77	8.47	0.57	2.69	3.13	2.89	C	1,345
	2.0+3.5+4.2	1.65	2.89	3.47	---	---	2.83	8.01	8.48	0.60	2.81	3.13	2.85	C	1,405
	2.0+3.5+5.0	1.58	2.77	3.95	---	---	2.95	8.30	8.66	0.61	2.96	3.16	2.80	D	1,480
	2.0+3.5+6.0	1.50	2.63	4.52	---	---	3.10	8.65	9.29	0.64	2.95	3.36	2.93	C	1,475
	2.0+3.5+7.1	1.43	2.50	5.07	---	---	3.26	9.00	9.31	0.68	3.15	3.36	2.86	C	1,575
	2.0+4.2+4.2	1.58	3.34	3.34	---	---	2.94	8.26	8.49	0.60	3.00	3.13	2.75	D	1,500
	2.0+4.2+5.0	1.53	3.20	3.81	---	---	3.05	8.54	8.84	0.64	3.09	3.29	2.76	D	1,545
	2.0+4.2+6.0	1.46	3.06	4.37	---	---	3.20	8.89	9.30	0.64	3.08	3.36	2.89	C	1,540
	2.0+4.2+7.1	1.36	2.84	4.80	---	---	3.36	9.00	9.32	0.68	3.15	3.36	2.86	C	1,575
	2.0+5.0+5.0	1.46	3.68	3.68	---	---	3.17	8.82	9.02	0.64	3.18	3.32	2.77	D	1,590
	2.0+5.0+6.0	1.39	3.46	4.15	---	---	3.32	9.00	9.47	0.68	2.97	3.39	3.03	B	1,485
	2.0+5.0+7.1	1.28	3.19	4.53	---	---	3.48	9.00	9.49	0.71	2.90	3.39	3.10	B	1,450
	2.0+6.0+6.0	1.28	3.86	3.86	---	---	3.46	9.00	9.93	0.68	2.68	3.46	3.36	A	1,340
	2.0+6.0+7.1	1.19	3.58	4.23	---	---	3.63	9.00	10.40	0.71	2.61	4.00	3.45	A	1,305
	2.5+2.5+2.5	2.41	2.41	2.41	---	---	2.51	7.23	7.64	0.54	2.34	2.57	3.09	B	1,170
	2.5+2.5+3.5	2.23	2.23	3.13	---	---	2.66	7.59	8.25	0.57	2.57	3.00	2.95	C	1,285
	2.5+2.5+4.2	2.13	2.13	3.58	---	---	2.76	7.84	8.47	0.57	2.69	3.13	2.91	C	1,345
	2.5+2.5+5.0	2.03	2.03	4.06	---	---	2.88	8.12	8.65	0.61	2.83	3.15	2.87	C	1,415
	2.5+2.5+6.0	1.93	1.93	4.61	---	---	3.02	8.47	9.10	0.61	2.82	3.22	3.00	C	1,410
	2.5+2.5+7.1	1.83	1.83	5.20	---	---	3.19	8.86	9.30	0.64	3.08	3.36	2.88	C	1,540
	2.5+3.5+3.5	2.08	2.93	2.93	---	---	2.80	7.94	8.47	0.60	2.75	3.13	2.89	C	1,375
	2.5+3.5+4.2	2.01	2.81	3.37	---	---	2.91	8.19	8.48	0.60	2.94	3.13	2.79	D	1,470
	2.5+3.5+5.0	1.93	2.70	3.84	---	---	3.02	8.47	8.66	0.64	3.02	3.16	2.80	D	1,510
	2.5+3.5+6.0	1.84	2.57	4.41	---	---	3.17	8.82	9.29	0.64	3.01	3.36	2.93	C	1,505
	2.5+3.5+7.1	1.72	2.40	4.88	---	---	3.33	9.00	9.31	0.68	3.15	3.36	2.86	C	1,575
	2.5+4.2+4.2	1.94	3.25	3.25	---	---	3.01	8.44	8.44	0.64	3.13	3.13	2.70	D	1,565
	2.5+4.2+5.0	1.86	3.13	3.73	---	---	3.13	8.72	8.84	0.64	3.22	3.29	2.71	D	1,610
	2.5+4.2+6.0	1.77	2.98	4.25	---	---	3.27	9.00	9.30	0.68	3.15	3.36	2.86	C	1,575
	2.5+4.2+7.1	1.63	2.74	4.63	---	---	3.44	9.00	9.32	0.71	3.15	3.36	2.86	C	1,575
	2.5+5.0+5.0	1.80	3.60	3.60	---	---	3.24	9.00	9.02	0.67	3.32	3.37	2.71	D	1,660
	2.5+5.0+6.0	1.67	3.33	4.00	---	---	3.39	9.00	9.47	0.68	3.04	3.39	2.96	C	1,520
	2.5+5.0+7.1	1.54	3.08	4.38	---	---	3.55	9.00	9.49	0.71	2.97	3.39	3.03	B	1,485
	2.5+6.0+6.0	1.56	3.72	3.72	---	---	3.54	9.00	9.93	0.71	2.75	3.46	3.27	A	1,375
	2.5+6.0+7.1	1.44	3.46	4.10	---	---	3.70	9.00	10.40	0.71	2.68	4.00	3.36	A	1,340
	3.5+3.5+3.5	2.77	2.77	2.77	---	---	2.95	8.31	8.60	0.64	3.07	3.26	2.71	D	1,535
	3.5+3.5+4.2	2.67	2.67	3.20	---	---	3.05	8.54	8.66	0.64	3.20	3.26	2.67	D	1,600
	3.5+3.5+5.0	2.57	2.57	3.68	---	---	3.17	8.82	8.84	0.67	3.29	3.32	2.68	D	1,645
	3.5+3.5+6.0	2.42	2.42	4.16	---	---	3.32	9.00	9.30	0.68	3.08	3.36	2.92	C	1,540
	3.5+3.5+7.1	2.23	2.23	4.54	---	---	3.48	9.00	9.32	0.71	3.02	3.36	2.98	C	1,510
	3.5+4.2+4.2	2.59	3.10	3.10	---	---	3.16	8.79	8.79	0.67	3.26	3.26	2.70	D	1,630
	3.5+4.2+5.0	2.48	2.98	3.54	---	---	3.27	9.00	9.00	0.67	3.29	3.29	2.74	D	1,645
	3.5+4.2+6.0	2.30	2.76	3.94	---	---	3.42	9.00	9.31	0.71	3.15	3.36	2.86	C	1,575
	3.5+4.2+7.1	2.13	2.55	4.32	---	---	3.58	9.00	9.81	0.75	3.15	3.95	2.86	C	1,575
	3.5+5.0+5.0	2.34	3.33	3.33	---	---	3.39	9.00	9.02	0.71	3.32	3.35	2.71	D	1,660
	3.5+5.0+6.0	2.18	3.10	3.72	---	---	3.54	9.00	9.48	0.71	3.04	3.39	2.96	C	1,520
	3.5+5.0+7.1	2.02	2.88	4.10	---	---	3.70	9.00	9.94	0.75	2.97	3.91	3.03	B	1,485
	3.5+6.0+6.0	2.04	3.48	3.48	---	---	3.69	9.00	10.38	0.71	2.75	4.00	3.27	A	1,375
	4.2+4.2+4.2	3.00	3.00	3.00	---	---	3.26	9.00	9.00	0.71	3.27	3.27	2.75	D	1,635

COOLING															
OUTDOOR UNIT	INDOOR UNIT	COOLING CAPACITY (kW)					TOTAL CAPACITY (kW)			POWER INPUT COOLING (kW)			EER	ENERGY LABEL	AEC (kWh)
		A ROOM	B ROOM	C ROOM	D ROOM	E ROOM	Min.	Nom.	Max.	Min.	Nom.	Max.			
5MXS90E	4.2+4.2+5.0	2.82	2.82	3.36	---	---	3.38	9.00	9.08	0.71	3.29	3.29	2.74	D	1,645
	4.2+4.2+6.0	2.63	2.63	3.74	---	---	3.52	9.00	9.32	0.71	3.15	3.36	2.86	C	1,575
	4.2+4.2+7.1	2.44	2.44	4.12	---	---	3.69	9.00	9.82	0.75	3.16	3.95	2.85	C	1,580
	4.2+5.0+5.0	2.66	3.17	3.17	---	---	3.49	9.00	9.03	0.74	3.32	3.32	2.71	D	1,660
	4.2+5.0+6.0	2.49	2.96	3.55	---	---	3.64	9.00	9.98	0.75	3.04	3.98	2.96	C	1,520
	5.0+5.0+5.0	3.00	3.00	3.00	---	---	3.61	9.00	9.78	0.75	3.21	4.07	2.80	D	1,605
	20+20+20+20	1.86	1.86	1.86	1.86	---	2.58	7.44	7.96	0.54	2.04	2.32	3.65	A	1,020
	20+20+20+25	1.79	1.79	1.79	2.22	---	2.66	7.59	8.25	0.54	2.09	2.50	3.63	A	1,045
	20+20+20+35	1.67	1.67	1.67	2.93	---	2.80	7.94	8.78	0.58	2.32	2.82	3.42	A	1,160
	20+20+20+42	1.61	1.61	1.61	3.36	---	2.91	8.19	9.12	0.61	2.63	3.22	3.11	B	1,315
	20+20+20+50	1.54	1.54	1.54	3.85	---	3.02	8.47	9.30	0.61	2.71	3.25	3.13	B	1,355
	20+20+20+60	1.47	1.47	1.47	4.41	---	3.17	8.82	9.81	0.65	2.68	3.38	3.29	A	1,340
	20+20+20+71	1.37	1.37	1.37	4.89	---	3.33	9.00	9.96	0.65	2.82	3.46	3.19	B	1,410
	20+20+25+25	1.73	1.73	2.16	2.16	---	2.73	7.78	8.53	0.58	2.21	2.69	3.52	A	1,105
	20+20+25+35	1.62	1.62	2.03	2.85	---	2.88	8.12	9.03	0.58	2.56	3.22	3.17	B	1,280
	20+20+25+42	1.56	1.56	1.96	3.29	---	2.98	8.37	9.13	0.61	2.69	3.22	3.11	B	1,345
	20+20+25+50	1.50	1.50	1.88	3.77	---	3.10	8.65	9.49	0.64	2.84	3.39	3.05	B	1,420
	20+20+25+60	1.44	1.44	1.80	4.32	---	3.24	9.00	9.94	0.65	2.81	3.46	3.20	B	1,405
	20+20+25+71	1.32	1.32	1.65	4.71	---	3.41	9.00	9.96	0.68	2.82	3.46	3.19	B	1,410
	20+20+35+35	1.54	1.54	2.70	2.70	---	3.02	8.48	9.13	0.61	2.82	3.22	3.01	B	1,410
	20+20+35+42	1.49	1.49	2.61	3.13	---	3.13	8.72	9.32	0.64	2.95	3.36	2.96	C	1,475
	20+20+35+50	1.44	1.44	2.52	3.60	---	3.24	9.00	9.49	0.64	3.04	3.39	2.96	C	1,520
	20+20+35+60	1.33	1.33	2.34	4.00	---	3.39	9.00	9.95	0.68	2.75	3.46	3.27	A	1,375
	20+20+35+71	1.23	1.23	2.16	4.38	---	3.55	9.00	9.97	0.71	2.68	3.46	3.36	A	1,340
	20+20+42+42	1.45	1.45	3.03	3.03	---	3.23	8.96	9.33	0.64	3.09	3.36	2.90	C	1,545
	20+20+42+50	1.36	1.36	2.87	3.41	---	3.35	9.00	9.50	0.68	3.04	3.39	2.96	C	1,520
	20+20+42+60	1.27	1.27	2.66	3.80	---	3.49	9.00	9.96	0.68	2.81	3.46	3.20	B	1,405
	20+20+42+71	1.18	1.18	2.47	4.17	---	3.66	9.00	10.47	0.71	2.75	4.01	3.27	A	1,375
	20+20+50+50	1.29	1.29	3.21	3.21	---	3.46	9.00	9.68	0.68	2.92	3.42	3.08	B	1,460
	20+20+50+60	1.20	1.20	3.00	3.60	---	3.61	9.00	10.45	0.71	2.70	3.88	3.33	A	1,350
	20+25+25+25	1.67	2.09	2.09	2.09	---	2.80	7.94	8.78	0.58	2.32	2.82	3.42	A	1,160
	20+25+25+35	1.57	1.98	1.98	2.77	---	2.95	8.30	9.12	0.61	2.69	3.22	3.09	B	1,345
	20+25+25+42	1.53	1.91	1.91	3.19	---	3.05	8.54	9.31	0.61	2.82	3.36	3.03	B	1,410
	20+25+25+50	1.46	1.84	1.84	3.68	---	3.17	8.82	9.49	0.64	2.90	3.39	3.04	B	1,450
	20+25+25+60	1.39	1.73	1.73	4.15	---	3.32	9.00	9.94	0.65	2.75	3.46	3.27	A	1,375
	20+25+25+71	1.27	1.60	1.60	4.53	---	3.48	9.00	9.96	0.68	2.68	3.46	3.36	A	1,340
	20+25+35+35	1.50	1.89	2.63	2.63	---	3.10	8.65	9.31	0.64	2.88	3.36	3.00	C	1,440
	20+25+35+42	1.46	1.82	2.55	3.06	---	3.20	8.89	9.32	0.64	3.08	3.36	2.89	C	1,540
	20+25+35+50	1.39	1.73	2.42	3.46	---	3.32	9.00	9.49	0.68	3.04	3.39	2.96	C	1,520
	20+25+35+60	1.28	1.61	2.25	3.86	---	3.46	9.00	9.95	0.68	2.75	3.46	3.27	A	1,375
	20+25+35+71	1.19	1.49	2.09	4.23	---	3.63	9.00	10.42	0.71	2.68	4.01	3.36	A	1,340
	20+25+42+42	1.40	1.74	2.93	2.93	---	3.30	9.00	9.33	0.68	3.15	3.36	2.86	C	1,575
	20+25+42+50	1.32	1.64	2.76	3.28	---	3.42	9.00	9.50	0.68	3.04	3.39	2.96	C	1,520
	20+25+42+60	1.23	1.53	2.57	3.67	---	3.57	9.00	10.41	0.71	2.81	4.00	3.20	B	1,405
	20+25+50+50	1.25	1.55	3.10	3.10	---	3.54	9.00	9.68	0.71	2.92	3.42	3.08	B	1,460
	20+25+50+60	1.17	1.45	2.90	3.48	---	3.69	9.00	10.49	0.71	2.70	3.96	3.33	A	1,350
	20+35+35+35	1.44	2.52	2.52	2.52	---	3.24	9.00	9.32	0.68	3.15	3.36	2.86	C	1,575
	20+35+35+42	1.36	2.39	2.39	2.86	---	3.35	9.00	9.33	0.68	3.15	3.36	2.86	C	1,575

COOLING															
OUTDOOR UNIT	INDOOR UNIT	COOLING CAPACITY (kW)					TOTAL CAPACITY (kW)			POWER INPUT COOLING (kW)			EER	ENERGY LABEL	AEC (kWh)
		A ROOM	B ROOM	C ROOM	D ROOM	E ROOM	Min.	Nom.	Max.	Min.	Nom.	Max.			
5MXS90E	20+35+35+50	1.29	2.25	2.25	3.21	---	3.46	9.00	9.50	0.71	3.04	3.39	2.96	C	1,520
	20+35+35+60	1.20	2.10	2.10	3.60	---	3.61	9.00	10.40	0.71	2.75	4.01	3.27	A	1,375
	20+35+42+42	1.29	2.27	2.72	2.72	---	3.45	9.00	9.33	0.71	3.16	3.37	2.85	C	1,580
	20+35+42+50	1.23	2.14	2.57	3.06	---	3.57	9.00	10.00	0.71	3.04	3.99	2.96	C	1,520
	20+35+50+50	1.17	2.03	2.90	2.90	---	3.69	9.00	10.26	0.75	2.92	4.19	3.08	B	1,460
	20+42+42+42	1.23	2.59	2.59	2.59	---	3.55	9.00	9.34	0.71	3.16	3.37	2.85	C	1,580
	20+42+42+50	1.18	2.45	2.45	2.92	---	3.67	9.00	10.01	0.75	3.04	3.99	2.96	C	1,520
	25+25+25+25	2.03	2.03	2.03	2.03	---	2.88	8.12	9.03	0.58	2.56	3.22	3.17	B	1,280
	25+25+25+35	1.93	1.93	1.93	2.68	---	3.02	8.47	9.12	0.61	2.82	3.22	3.00	C	1,410
	25+25+25+42	1.87	1.86	1.86	3.13	---	3.13	8.72	9.31	0.64	2.95	3.36	2.96	C	1,475
	25+25+25+50	1.80	1.80	1.80	3.60	---	3.24	9.00	9.49	0.64	3.04	3.39	2.96	C	1,520
	25+25+25+60	1.67	1.67	1.67	3.99	---	3.39	9.00	9.94	0.68	2.75	3.46	3.27	A	1,375
	25+25+25+71	1.54	1.54	1.54	4.38	---	3.55	9.00	9.96	0.71	2.68	3.46	3.36	A	1,340
	25+25+35+35	1.84	1.84	2.57	2.57	---	3.17	8.82	9.31	0.64	3.02	3.36	2.92	C	1,510
	25+25+35+42	1.77	1.77	2.48	2.98	---	3.27	9.00	9.32	0.68	3.15	3.36	2.86	C	1,575
	25+25+35+50	1.67	1.67	2.33	3.33	---	3.39	9.00	9.49	0.68	3.04	3.39	2.96	C	1,520
	25+25+35+60	1.55	1.55	2.18	3.72	---	3.54	9.00	9.95	0.71	2.75	3.46	3.27	A	1,375
	25+25+35+71	1.44	1.44	2.02	4.10	---	3.70	9.00	10.42	0.71	2.68	4.01	3.36	A	1,340
	25+25+42+42	1.68	1.68	2.82	2.82	---	3.38	9.00	9.33	0.68	3.15	3.36	2.86	C	1,575
	25+25+42+50	1.58	1.58	2.67	3.17	---	3.49	9.00	9.50	0.71	3.04	3.39	2.96	C	1,520
	25+25+42+60	1.48	1.48	2.49	3.55	---	3.64	9.00	10.47	0.71	2.81	4.00	3.20	B	1,405
	25+25+50+50	1.50	1.50	3.00	3.00	---	3.61	9.00	10.25	0.71	2.92	4.18	3.08	B	1,460
	25+35+35+35	1.74	2.42	2.42	2.42	---	3.32	9.00	9.34	0.68	3.15	3.36	2.86	C	1,575
	25+35+35+42	1.64	2.30	2.30	2.76	---	3.42	9.00	9.33	0.71	3.15	3.36	2.86	C	1,575
	25+35+35+50	1.56	2.17	2.17	3.10	---	3.54	9.00	9.50	0.71	3.04	3.39	2.96	C	1,520
	25+35+35+60	1.46	2.03	2.03	3.48	---	3.69	9.00	10.40	0.71	2.75	4.01	3.27	A	1,375
	25+35+42+42	1.56	2.18	2.63	2.63	---	3.52	9.00	9.33	0.71	3.16	3.37	2.85	C	1,580
	25+35+42+50	1.48	2.07	2.49	2.96	---	3.64	9.00	10.00	0.75	3.04	3.99	2.96	C	1,520
	25+42+42+42	1.50	2.50	2.50	2.50	---	3.63	9.00	9.83	0.75	3.16	3.95	2.85	C	1,580
	35+35+35+35	2.25	2.25	2.25	2.25	---	3.46	9.00	9.32	0.71	3.15	3.36	2.86	C	1,575
	35+35+35+42	2.14	2.14	2.14	2.58	---	3.57	9.00	9.82	0.75	3.16	3.95	2.85	C	1,580
	35+35+35+50	2.03	2.03	2.03	2.91	---	3.69	9.00	9.95	0.75	3.04	3.91	2.96	C	1,520
	35+35+42+42	2.05	2.05	2.45	2.45	---	3.67	9.00	9.83	0.75	3.16	3.95	2.85	C	1,580
	20+20+20+20+20	1.63	1.63	1.63	1.63	1.63	2.88	8.15	9.03	0.58	2.30	2.81	3.54	A	1,150
	20+20+20+20+25	1.58	1.58	1.58	1.58	1.98	2.95	8.30	9.25	0.58	2.36	2.95	3.52	A	1,180
	20+20+20+20+35	1.50	1.50	1.50	1.50	2.65	3.10	8.65	9.64	0.61	2.55	3.24	3.39	A	1,275
	20+20+20+20+42	1.46	1.46	1.46	1.46	3.05	3.20	8.89	9.87	0.65	2.68	3.39	3.32	A	1,340
	20+20+20+20+50	1.38	1.38	1.38	1.38	3.48	3.32	9.00	10.09	0.65	2.70	3.49	3.33	A	1,350
	20+20+20+20+60	1.29	1.29	1.29	1.29	3.84	3.46	9.00	10.31	0.65	2.50	3.40	3.60	A	1,250
	20+20+20+20+71	1.19	1.19	1.19	1.19	4.24	3.63	9.00	10.46	0.68	2.47	3.48	3.64	A	1,235
	20+20+20+25+25	1.54	1.54	1.54	1.92	1.92	3.02	8.46	9.45	0.61	2.49	3.09	3.40	A	1,245
	20+20+20+25+35	1.47	1.47	1.47	1.84	2.57	3.17	8.82	9.81	0.61	2.68	3.39	3.29	A	1,340
	20+20+20+25+42	1.42	1.42	1.42	1.77	2.97	3.27	9.00	9.97	0.65	2.82	3.46	3.19	B	1,410
	20+20+20+25+50	1.33	1.33	1.33	1.67	3.34	3.39	9.00	10.15	0.65	2.70	3.49	3.33	A	1,350
	20+20+20+25+60	1.24	1.24	1.24	1.55	3.73	3.54	9.00	10.38	0.68	2.50	3.40	3.60	A	1,250
	20+20+20+25+71	1.15	1.15	1.15	1.44	4.11	3.70	9.00	10.50	0.71	2.47	3.48	3.64	A	1,235
	20+20+20+35+35	1.54	1.54	1.54	1.92	1.92	3.02	8.46	9.45	0.61	2.49	3.09	3.40	A	1,245
	20+20+20+35+42	1.31	1.31	1.31	2.31	2.76	3.42	9.00	9.98	0.68	2.75	3.46	3.27	A	1,375

COOLING															
OUTDOOR UNIT	INDOOR UNIT	COOLING CAPACITY (kW)					TOTAL CAPACITY (kW)			POWER INPUT COOLING (kW)			EER	ENERGY LABEL	AEC (kWh)
		A ROOM	B ROOM	C ROOM	D ROOM	E ROOM	Min.	Nom.	Max.	Min.	Nom.	Max.			
5MXS90E	20+20+20+35+50	1.24	1.24	1.24	2.17	3.11	3.54	9.00	10.16	0.68	2.74	3.49	3.28	A	1,370
	20+20+20+35+60	1.16	1.16	1.16	2.03	3.49	3.69	9.00	10.49	0.71	2.46	3.48	3.66	A	1,230
	20+20+20+42+42	1.24	1.24	1.24	2.64	2.64	3.52	9.00	9.99	0.68	2.75	3.47	3.27	A	1,375
	20+20+20+42+50	1.18	1.18	1.18	2.50	2.96	3.64	9.00	10.47	0.71	2.70	3.89	3.33	A	1,350
	20+20+25+25+35	1.51	1.51	1.88	1.88	1.88	3.10	8.66	9.64	0.61	2.55	3.24	3.40	A	1,275
	20+20+25+25+35	1.44	1.44	1.80	1.80	2.52	3.24	9.00	9.96	0.65	2.82	3.46	3.19	B	1,410
	20+20+25+25+42	1.37	1.37	1.70	1.70	2.86	3.35	9.00	9.66	0.65	2.86	3.46	3.15	B	1,430
	20+20+25+25+50	1.29	1.29	1.61	1.61	3.20	3.46	9.00	10.15	0.68	2.70	3.49	3.33	A	1,350
	20+20+25+25+60	1.20	1.20	1.50	1.50	3.60	3.61	9.00	10.45	0.68	2.46	3.48	3.66	A	1,230
	20+20+25+35+35	1.33	1.33	1.68	2.33	2.33	3.39	9.00	9.97	0.68	2.82	3.46	3.19	B	1,410
	20+20+25+35+42	1.27	1.27	1.58	2.22	2.66	3.49	9.00	9.66	0.68	2.79	3.46	3.23	A	1,395
	20+20+25+35+50	1.20	1.20	1.50	2.10	3.00	3.61	9.00	10.45	0.71	2.70	3.80	3.33	A	1,350
	20+20+25+35+42	1.21	1.21	1.50	2.54	2.54	3.60	9.00	10.44	0.71	2.75	4.01	3.27	A	1,375
	20+20+35+35+35	1.23	1.23	2.18	2.18	2.18	3.54	9.00	9.98	0.68	2.82	3.46	3.19	B	1,410
	20+20+35+35+42	1.18	1.18	2.07	2.07	2.50	3.64	9.00	10.47	0.71	2.75	4.01	3.27	A	1,375
	20+20+35+35+50	1.46	1.84	1.84	1.84	1.84	3.17	8.82	9.81	0.61	2.68	3.39	3.29	A	1,340
	20+25+25+35+35	1.39	1.73	1.73	1.73	2.42	3.32	9.00	9.96	0.65	2.82	3.46	3.19	B	1,410
	20+25+25+35+42	1.32	1.64	1.64	1.64	2.76	3.42	9.00	9.97	0.68	2.82	3.46	3.19	B	1,410
	20+25+25+35+50	1.25	1.55	1.55	1.55	3.10	3.54	9.00	10.15	0.68	2.70	3.49	3.33	A	1,350
	20+25+25+35+60	1.17	1.45	1.45	1.45	3.48	3.69	9.00	10.49	0.71	2.46	3.48	3.66	A	1,230
	20+25+25+35+35	1.28	1.61	1.61	2.25	2.25	3.46	9.00	9.97	0.68	2.82	3.46	3.19	B	1,410
	20+25+25+35+42	1.23	1.53	1.53	2.14	2.57	3.57	9.00	10.41	0.71	2.75	4.01	3.27	A	1,375
	20+25+25+35+50	1.17	1.45	1.45	2.03	2.90	3.69	9.00	10.49	0.71	2.70	3.88	3.33	A	1,350
	20+25+25+42+42	1.18	1.46	1.46	2.45	2.45	3.64	9.00	10.47	0.71	2.75	4.01	3.27	A	1,375
	20+25+35+35+35	1.20	1.50	2.10	2.10	2.10	3.61	9.00	10.42	0.71	2.82	4.01	3.19	B	1,410
	25+25+25+25+25	1.80	1.80	1.80	1.80	1.80	3.24	9.00	9.95	0.65	2.81	3.46	3.20	B	1,405
	25+25+25+25+35	1.67	1.67	1.67	1.67	2.32	3.39	9.00	9.96	0.68	2.75	3.46	3.27	A	1,375
	25+25+25+25+42	1.58	1.58	1.58	1.58	2.68	3.49	9.00	9.97	0.68	2.82	3.46	3.19	B	1,410
	25+25+25+25+50	1.50	1.50	1.50	1.50	3.00	3.61	9.00	10.45	0.71	2.70	3.88	3.33	A	1,350
	25+25+25+35+35	1.56	1.56	1.56	2.16	2.16	3.54	9.00	9.97	0.68	2.82	3.46	3.19	B	1,410
	25+25+25+35+42	1.48	1.48	1.48	2.07	2.49	3.64	9.00	10.47	0.71	2.75	4.01	3.27	A	1,375
	25+25+35+35+35	1.44	1.44	2.04	2.04	2.04	3.69	9.00	10.42	0.71	2.75	4.01	3.27	A	1,375

HEATING														
OUTDOOR UNIT	INDOOR UNIT	HEATING CAPACITY (kW)					TOTAL CAPACITY (kW)			POWER INPUT HEATING (kW)			COP	ENERGY LABEL
		A ROOM	B ROOM	C ROOM	D ROOM	E ROOM	Min.	Nom.	Max.	Min.	Nom.	Max.		
5MXS90E	2.0	2.44	---	---	---	---	1.36	2.44	4.20	0.35	0.68	1.38	3.59	B
	2.5	3.05	---	---	---	---	1.42	3.05	4.65	0.37	0.90	1.48	3.39	C
	3.5	4.27	---	---	---	---	1.54	4.27	5.11	0.39	1.43	1.95	2.99	D
	4.2	5.12	---	---	---	---	1.75	5.12	5.16	0.60	1.73	1.98	2.96	D
	5.0	6.09	---	---	---	---	1.98	6.09	7.42	0.48	1.91	2.48	3.19	D
	6.0	7.31	---	---	---	---	2.28	7.31	8.53	0.60	2.30	2.89	3.18	D
	7.1	8.65	---	---	---	---	2.60	8.65	9.02	0.67	2.87	3.04	3.01	D
	2.0+2.0	2.44	2.44	---	---	---	1.69	4.88	6.85	0.39	1.21	1.87	4.03	A
	2.0+2.5	2.44	3.05	---	---	---	1.84	5.49	7.25	0.41	1.40	2.05	3.92	A
	2.0+3.5	2.44	4.26	---	---	---	2.13	6.70	7.74	0.50	1.99	2.44	3.37	C
	2.0+4.2	2.44	5.11	---	---	---	2.34	7.55	8.53	0.62	2.33	2.81	3.24	C
	2.0+5.0	2.44	6.09	---	---	---	2.57	8.53	9.09	0.63	2.45	2.66	3.48	B
	2.0+6.0	2.32	6.95	---	---	---	2.86	9.27	9.88	0.65	2.63	2.96	3.52	B
	2.0+7.1	2.20	7.83	---	---	---	3.17	10.03	10.37	0.69	3.01	3.18	3.33	C
	2.5+2.5	3.04	3.04	---	---	---	1.98	6.08	7.46	0.47	1.76	2.35	3.45	B
	2.5+3.5	3.05	4.26	---	---	---	2.28	7.31	8.53	0.60	2.34	2.94	3.12	D
	2.5+4.2	3.04	5.12	---	---	---	2.49	8.16	9.02	0.65	2.76	3.18	2.96	D
	2.5+5.0	2.98	5.95	---	---	---	2.72	8.93	9.70	0.66	2.61	2.99	3.42	B
	2.5+6.0	2.83	6.79	---	---	---	3.00	9.62	9.88	0.67	2.86	3.03	3.36	C
	2.5+7.1	2.70	7.68	---	---	---	3.31	10.38	10.77	0.72	3.22	3.46	3.22	C
	3.5+3.5	4.27	4.27	---	---	---	2.57	8.54	9.02	0.65	2.91	3.15	2.93	D
	3.5+4.2	4.12	4.94	---	---	---	2.77	9.06	9.60	0.70	3.21	3.53	2.82	D
	3.5+5.0	3.96	5.66	---	---	---	3.00	9.62	9.70	0.71	2.93	2.98	3.28	C
	3.5+6.0	3.80	6.51	---	---	---	3.28	10.31	10.75	0.72	3.19	3.43	3.23	C
	3.5+7.1	3.43	6.97	---	---	---	3.59	10.40	10.78	0.77	3.11	3.35	3.34	C
	4.2+4.2	4.77	4.77	---	---	---	2.97	9.54	9.61	0.72	3.47	3.53	2.75	E
	4.2+5.0	4.61	5.49	---	---	---	3.20	10.10	10.12	0.73	3.22	3.28	3.14	D
	4.2+6.0	4.28	6.12	---	---	---	3.48	10.40	10.76	0.75	3.24	3.42	3.21	C
	4.2+7.1	3.87	6.53	---	---	---	3.79	10.40	10.78	0.79	3.11	3.34	3.34	C
	5.0+5.0	5.20	5.20	---	---	---	3.42	10.40	10.64	0.76	3.28	3.40	3.17	D
	5.0+6.0	4.73	5.67	---	---	---	3.70	10.40	10.88	0.75	3.08	3.31	3.38	C
	5.0+7.1	4.30	6.10	---	---	---	4.01	10.40	10.51	0.83	3.01	3.06	3.46	B
	6.0+6.0	5.20	5.20	---	---	---	3.99	10.40	10.71	0.76	2.88	3.04	3.61	A
	6.0+7.1	4.76	5.64	---	---	---	4.30	10.40	10.74	0.84	2.86	3.03	3.64	A
	7.1+7.1	5.20	5.20	---	---	---	4.61	10.40	10.77	0.89	2.85	3.02	3.65	A
	2.0+2.0+2.0	2.44	2.44	2.44	---	---	2.28	7.32	8.67	0.53	1.84	2.32	3.98	A
	2.0+2.0+2.5	2.44	2.44	3.04	---	---	2.43	7.92	9.21	0.55	2.05	2.58	3.86	A
	2.0+2.0+3.5	2.38	2.38	4.17	---	---	2.72	8.93	9.89	0.60	2.42	2.89	3.69	A
	2.0+2.0+4.2	2.30	2.30	4.81	---	---	2.91	9.41	9.89	0.64	2.62	2.89	3.59	B
	2.0+2.0+5.0	2.21	2.21	5.54	---	---	3.14	9.96	10.48	0.65	2.84	3.07	3.51	B
	2.0+2.0+6.0	2.08	2.08	6.24	---	---	3.42	10.40	10.71	0.66	2.87	3.04	3.62	A
	2.0+2.0+7.1	1.87	1.87	6.66	---	---	3.73	10.40	10.75	0.70	2.86	3.03	3.64	A
	2.0+2.5+2.5	2.43	3.05	3.05	---	---	2.57	8.53	9.21	0.57	2.28	2.58	3.74	A
	2.0+2.5+3.5	2.31	2.90	4.06	---	---	2.86	9.27	9.89	0.62	2.57	2.89	3.61	A
	2.0+2.5+4.2	2.24	2.80	4.71	---	---	3.06	9.75	10.36	0.67	2.78	3.12	3.51	B
	2.0+2.5+5.0	2.17	2.71	5.43	---	---	3.28	10.31	10.48	0.67	3.02	3.07	3.41	B
	2.0+2.5+6.0	1.98	2.48	5.94	---	---	3.56	10.40	10.71	0.68	2.87	3.04	3.62	A
	2.0+2.5+7.1	1.79	2.24	6.37	---	---	3.87	10.40	10.75	0.73	2.86	3.03	3.64	A

HEATING														
OUTDOOR UNIT	INDOOR UNIT	HEATING CAPACITY (kW)					TOTAL CAPACITY (kW)			POWER INPUT HEATING (kW)			COP	ENERGY LABEL
		A ROOM	B ROOM	C ROOM	D ROOM	E ROOM	Min.	Nom.	Max.	Min.	Nom.	Max.		
5MXS90E	2.0+3.5+3.5	2.22	3.87	3.87	---	---	3.14	9.96	10.36	0.69	2.89	3.12	3.45	B
	2.0+3.5+4.2	2.14	3.75	4.51	---	---	3.34	10.40	10.55	0.72	3.18	3.23	3.27	C
	2.0+3.5+5.0	1.98	3.47	4.95	---	---	3.56	10.40	10.90	0.72	3.07	3.30	3.39	C
	2.0+3.5+6.0	1.80	3.17	5.43	---	---	3.84	10.40	10.72	0.73	2.87	3.04	3.62	A
	2.0+3.5+7.1	1.65	2.89	5.86	---	---	4.15	10.40	10.75	0.81	2.86	3.03	3.64	A
	2.0+4.2+4.2	2.00	4.20	4.20	---	---	3.53	10.40	10.56	0.74	3.12	3.23	3.33	C
	2.0+4.2+5.0	1.86	3.90	4.64	---	---	3.76	10.40	10.91	0.77	3.07	3.30	3.39	C
	2.0+4.2+6.0	1.70	3.58	5.12	---	---	4.04	10.40	10.73	0.78	2.87	3.04	3.62	A
	2.0+4.2+7.1	1.56	3.28	5.56	---	---	4.35	10.40	10.76	0.83	2.86	3.02	3.64	A
	2.0+5.0+5.0	1.74	4.33	4.33	---	---	3.99	10.40	10.63	0.80	2.96	3.08	3.51	B
	2.0+5.0+6.0	1.60	4.00	4.80	---	---	4.27	10.40	10.86	0.79	2.77	2.99	3.75	A
	2.0+5.0+7.1	1.47	3.69	5.24	---	---	4.58	10.40	10.89	0.86	2.75	2.97	3.78	A
	2.0+6.0+6.0	1.48	4.46	4.46	---	---	4.55	10.40	11.09	0.82	2.62	2.90	3.97	A
	2.0+6.0+7.1	1.38	4.13	4.89	---	---	4.86	10.40	11.12	0.87	2.61	2.89	3.98	A
	2.5+2.5+2.5	2.98	2.98	2.98	---	---	2.72	8.94	9.88	0.60	2.42	2.89	3.69	A
	2.5+2.5+3.5	2.83	2.83	3.96	---	---	3.00	9.62	9.89	0.67	2.73	2.89	3.52	B
	2.5+2.5+4.2	2.74	2.74	4.62	---	---	3.20	10.10	10.36	0.69	3.01	3.12	3.36	C
	2.5+2.5+5.0	2.60	2.60	5.20	---	---	3.42	10.40	10.89	0.70	3.07	3.30	3.39	C
	2.5+2.5+6.0	2.36	2.36	5.68	---	---	3.70	10.40	10.71	0.71	2.87	3.04	3.62	A
	2.5+2.5+7.1	2.15	2.15	6.10	---	---	4.01	10.40	10.75	0.78	2.86	3.03	3.64	A
	2.5+3.5+3.5	2.71	3.80	3.80	---	---	3.28	10.31	10.76	0.72	3.12	3.35	3.30	C
	2.5+3.5+4.2	2.55	3.57	4.28	---	---	3.48	10.40	10.77	0.74	3.18	3.35	3.27	C
	2.5+3.5+5.0	2.36	3.31	4.73	---	---	3.70	10.40	10.90	0.75	3.07	3.30	3.39	C
	2.5+3.5+6.0	2.17	3.03	5.20	---	---	3.99	10.40	10.72	0.76	2.87	3.04	3.62	A
	2.5+3.5+7.1	1.98	2.78	5.64	---	---	4.30	10.40	10.75	0.83	2.86	3.03	3.64	A
	2.5+4.2+4.2	2.38	4.01	4.01	---	---	3.68	10.40	10.77	0.77	3.12	3.35	3.33	C
	2.5+4.2+5.0	2.23	3.73	4.44	---	---	3.90	10.40	10.91	0.80	3.07	3.30	3.39	C
	2.5+4.2+6.0	2.05	3.44	4.91	---	---	4.18	10.40	10.73	0.81	2.87	3.04	3.62	A
	2.5+4.2+7.1	1.88	3.17	5.35	---	---	4.49	10.40	10.76	0.86	2.86	3.02	3.64	A
	2.5+5.0+5.0	2.08	4.16	4.16	---	---	4.13	10.40	10.63	0.83	2.96	3.08	3.51	B
	2.5+5.0+6.0	1.93	3.85	4.62	---	---	4.41	10.40	10.86	0.84	2.77	2.99	3.75	A
	2.5+5.0+7.1	1.78	3.56	5.06	---	---	4.72	10.40	10.89	0.89	2.75	2.97	3.78	A
	2.5+6.0+6.0	1.80	4.30	4.30	---	---	4.69	10.40	11.09	0.85	2.62	2.90	3.97	A
	2.5+6.0+7.1	1.67	4.00	4.73	---	---	5.00	10.40	11.12	0.90	2.61	2.89	3.98	A
	3.5+3.5+3.5	3.46	3.46	3.46	---	---	3.56	10.38	10.76	0.77	3.12	3.35	3.33	C
	3.5+3.5+4.2	3.25	3.25	3.90	---	---	3.76	10.40	10.77	0.80	3.12	3.35	3.33	C
	3.5+3.5+5.0	3.03	3.03	4.34	---	---	3.99	10.40	10.91	0.83	3.07	3.30	3.39	C
	3.5+3.5+6.0	2.80	2.80	4.80	---	---	4.27	10.40	10.73	0.84	2.87	3.04	3.62	A
	3.5+3.5+7.1	2.58	2.58	5.24	---	---	4.58	10.40	10.76	0.89	2.86	3.02	3.64	A
	3.5+4.2+4.2	3.06	3.67	3.67	---	---	3.96	10.40	10.78	0.85	3.11	3.34	3.34	C
	3.5+4.2+5.0	2.87	3.44	4.09	---	---	4.18	10.40	10.51	0.85	3.01	3.12	3.46	B
	3.5+4.2+6.0	2.66	3.19	4.55	---	---	4.46	10.40	10.74	0.87	2.87	3.03	3.62	A
	3.5+4.2+7.1	2.46	2.95	4.99	---	---	4.78	10.40	10.77	0.95	2.85	3.02	3.65	A
	3.5+5.0+5.0	2.70	3.85	3.85	---	---	4.41	10.40	10.64	0.89	2.96	3.07	3.51	B
	3.5+5.0+6.0	2.51	3.59	4.30	---	---	4.69	10.40	10.86	0.90	2.76	2.98	3.77	A
	3.5+5.0+7.1	2.34	3.33	4.73	---	---	5.00	10.40	10.90	0.95	2.75	2.97	3.78	A
	3.5+6.0+6.0	2.34	4.03	4.03	---	---	4.97	10.40	11.09	0.91	2.62	2.90	3.97	A
	4.2+4.2+4.2	3.47	3.47	3.47	---	---	4.15	10.40	10.79	0.88	3.11	3.34	3.34	C

HEATING														
OUTDOOR UNIT	INDOOR UNIT	HEATING CAPACITY (kW)					TOTAL CAPACITY (kW)			POWER INPUT HEATING (kW)			COP	ENERGY LABEL
		A ROOM	B ROOM	C ROOM	D ROOM	E ROOM	Min.	Nom.	Max.	Min.	Nom.	Max.		
5MXS90E	4.2+4.2+5.0	3.26	3.26	3.88	---	---	4.38	10.40	10.52	0.91	3.00	3.12	3.47	B
	4.2+4.2+6.0	3.03	3.03	4.34	---	---	4.66	10.40	10.75	0.92	2.86	3.03	3.64	A
	4.2+4.2+7.1	2.82	2.82	4.76	---	---	4.97	10.40	10.78	0.98	2.85	3.02	3.65	A
	4.2+5.0+5.0	3.08	3.66	3.66	---	---	4.61	10.40	10.64	0.91	2.96	3.07	3.51	B
	4.2+5.0+6.0	2.87	3.42	4.11	---	---	4.89	10.40	10.87	0.93	2.76	2.98	3.77	A
	5.0+5.0+5.0	3.46	3.46	3.46	---	---	4.83	10.38	10.77	0.95	2.85	3.02	3.64	A
	20+20+20+20	2.32	2.32	2.32	2.32	---	2.86	9.28	10.18	0.57	2.39	2.76	3.88	A
	20+20+20+25	2.26	2.26	2.26	2.84	---	3.00	9.62	10.18	0.59	2.49	2.76	3.86	A
	20+20+20+35	2.17	2.17	2.17	3.80	---	3.28	10.31	10.73	0.63	2.81	3.04	3.67	A
	20+20+20+42	2.04	2.04	2.04	4.28	---	3.48	10.40	10.74	0.66	2.87	3.03	3.62	A
	20+20+20+50	1.89	1.89	1.89	4.73	---	3.70	10.40	10.86	0.68	2.76	2.99	3.77	A
	20+20+20+60	1.73	1.73	1.73	5.21	---	3.99	10.40	11.09	0.69	2.62	2.90	3.97	A
	20+20+20+71	1.59	1.59	1.59	5.63	---	4.30	10.40	11.12	0.74	2.61	2.88	3.98	A
	20+20+25+25	2.21	2.21	2.77	2.77	---	3.14	9.96	10.72	0.61	2.65	3.04	3.76	A
	20+20+25+35	2.08	2.08	2.60	3.64	---	3.42	10.40	10.73	0.66	2.87	3.04	3.62	A
	20+20+25+42	1.94	1.94	2.44	4.08	---	3.62	10.40	10.74	0.68	2.87	3.03	3.62	A
	20+20+25+50	1.81	1.81	2.26	4.52	---	3.84	10.40	10.86	0.71	2.76	2.99	3.77	A
	20+20+25+60	1.66	1.66	2.08	5.00	---	4.13	10.40	11.09	0.72	2.62	2.90	3.97	A
	20+20+25+71	1.53	1.53	1.91	5.43	---	4.44	10.40	11.12	0.79	2.61	2.88	3.98	A
	20+20+35+35	1.89	1.89	3.31	3.31	---	3.70	10.40	10.74	0.71	2.87	3.03	3.62	A
	20+20+35+42	1.78	1.78	3.11	3.73	---	3.90	10.40	10.74	0.76	2.86	3.03	3.64	A
	20+20+35+50	1.66	1.66	2.91	4.17	---	4.13	10.40	10.87	0.76	2.76	2.98	3.77	A
	20+20+35+60	1.54	1.54	2.70	4.62	---	4.41	10.40	11.10	0.77	2.61	2.89	3.98	A
	20+20+35+71	1.42	1.42	2.49	5.07	---	4.72	10.40	11.13	0.84	2.60	2.88	4.00	A
	20+20+42+42	1.68	1.68	3.52	3.52	---	4.10	10.40	10.75	0.78	2.86	3.03	3.64	A
	20+20+42+50	1.58	1.58	3.31	3.93	---	4.32	10.40	10.88	0.81	2.76	2.98	3.77	A
	20+20+42+60	1.46	1.46	3.09	4.39	---	4.61	10.40	11.11	0.82	2.61	2.89	3.98	A
	20+20+42+71	1.36	1.36	2.85	4.83	---	4.92	10.40	11.14	0.90	2.60	2.88	4.00	A
	20+20+50+50	1.49	1.49	3.71	3.71	---	4.55	10.40	11.01	0.84	2.71	2.93	3.84	A
	20+20+50+60	1.39	1.39	3.47	4.15	---	4.83	10.40	11.23	0.85	2.51	2.90	4.14	A
	20+25+25+25	2.18	2.71	2.71	2.71	---	3.28	10.31	10.72	0.64	2.82	3.04	3.66	A
	20+25+25+35	1.97	2.48	2.48	3.47	---	3.56	10.40	10.73	0.68	2.87	3.04	3.62	A
	20+25+25+42	1.86	2.32	2.32	3.90	---	3.76	10.40	10.74	0.73	2.87	3.03	3.62	A
	20+25+25+50	1.73	2.17	2.17	4.33	---	3.99	10.40	10.86	0.73	2.76	2.99	3.77	A
	20+25+25+60	1.60	2.00	2.00	4.80	---	4.27	10.40	11.09	0.74	2.62	2.90	3.97	A
	20+25+25+71	1.48	1.84	1.84	5.24	---	4.58	10.40	11.12	0.82	2.61	2.88	3.98	A
	20+25+35+35	1.80	2.26	3.17	3.17	---	3.84	10.40	10.74	0.73	2.87	3.03	3.62	A
	20+25+35+42	1.71	2.13	2.98	3.58	---	4.04	10.40	10.74	0.78	2.86	3.03	3.64	A
	20+25+35+50	1.60	2.00	2.80	4.00	---	4.27	10.40	10.87	0.78	2.76	2.98	3.77	A
	20+25+35+60	1.48	1.86	2.60	4.46	---	4.55	10.40	11.10	0.82	2.61	2.89	3.98	A
	20+25+35+71	1.38	1.72	2.41	4.89	---	4.86	10.40	11.13	0.87	2.60	2.88	4.00	A
	20+25+42+42	1.61	2.01	3.39	3.39	---	4.24	10.40	10.75	0.81	2.86	3.03	3.64	A
	20+25+42+50	1.52	1.90	3.19	3.79	---	4.46	10.40	10.88	0.84	2.76	2.98	3.77	A
	20+25+42+60	1.42	1.77	2.97	4.24	---	4.75	10.40	11.11	0.85	2.61	2.89	3.98	A
	20+25+50+50	1.43	1.79	3.59	3.59	---	4.69	10.40	11.01	0.87	2.71	2.93	3.84	A
	20+25+50+60	1.34	1.68	3.35	4.03	---	4.97	10.40	11.23	0.88	2.51	2.90	4.14	A
	20+35+35+35	1.67	2.91	2.91	2.91	---	4.13	10.40	10.74	0.78	2.86	3.03	3.64	A
	20+35+35+42	1.58	2.76	2.76	3.30	---	4.32	10.40	10.75	0.84	2.86	3.03	3.64	A

HEATING														
OUTDOOR UNIT	INDOOR UNIT	HEATING CAPACITY (kW)					TOTAL CAPACITY (kW)			POWER INPUT HEATING (kW)			COP	ENERGY LABEL
		A ROOM	B ROOM	C ROOM	D ROOM	E ROOM	Min.	Nom.	Max.	Min.	Nom.	Max.		
5MXS90E	20+35+35+5.0	1.49	2.60	2.60	3.71	---	4.55	10.40	10.88	0.87	2.76	2.98	3.77	A
	20+35+35+6.0	1.38	2.43	2.43	4.16	---	4.83	10.40	11.11	0.87	2.61	2.89	3.98	A
	20+35+42+4.2	1.50	2.62	3.14	3.14	---	4.52	10.40	10.76	0.89	2.86	3.02	3.64	A
	20+35+42+5.0	1.41	2.48	2.97	3.54	---	4.75	10.40	10.89	0.89	2.75	2.98	3.78	A
	20+35+50+5.0	1.35	2.35	3.35	3.35	---	4.97	10.40	11.01	0.92	2.65	2.93	3.92	A
	20+42+42+4.2	1.43	2.99	2.99	2.99	---	4.72	10.40	10.77	0.92	2.85	3.02	3.65	A
	20+42+42+5.0	1.35	2.84	2.84	3.37	---	4.94	10.40	10.90	0.95	2.75	2.97	3.78	A
	25+25+25+2.5	2.60	2.60	2.60	2.60	---	3.42	10.40	10.72	0.66	2.87	3.04	3.62	A
	25+25+25+3.5	2.36	2.36	2.36	3.32	---	3.70	10.40	10.73	0.71	2.87	3.04	3.62	A
	25+25+25+4.2	2.22	2.22	2.22	3.74	---	3.90	10.40	10.74	0.76	2.87	3.03	3.62	A
	25+25+25+5.0	2.08	2.08	2.08	4.16	---	4.13	10.40	10.86	0.76	2.76	2.99	3.77	A
	25+25+25+6.0	1.93	1.93	1.93	4.61	---	4.41	10.40	11.09	0.77	2.62	2.90	3.97	A
	25+25+25+7.1	1.78	1.78	1.78	5.06	---	4.72	10.40	11.12	0.84	2.61	2.88	3.98	A
	25+25+35+3.5	2.17	2.17	3.03	3.03	---	3.99	10.40	10.74	0.76	2.87	3.03	3.62	A
	25+25+35+4.2	2.05	2.05	2.87	3.43	---	4.18	10.40	10.74	0.81	2.86	3.03	3.64	A
	25+25+35+5.0	1.93	1.93	2.70	3.84	---	4.41	10.40	10.87	0.84	2.76	2.98	3.77	A
	25+25+35+6.0	1.79	1.79	2.51	4.31	---	4.69	10.40	11.10	0.85	2.61	2.89	3.98	A
	25+25+35+7.1	1.67	1.67	2.33	4.73	---	5.00	10.40	11.13	0.90	2.60	2.88	4.00	A
	25+25+42+4.2	1.94	1.94	3.26	3.26	---	4.38	10.40	10.75	0.84	2.86	3.03	3.64	A
	25+25+42+5.0	1.83	1.83	3.08	3.66	---	4.61	10.40	10.88	0.87	2.76	2.98	3.77	A
	25+25+42+6.0	1.71	1.71	2.87	4.11	---	4.89	10.40	11.11	0.87	2.61	2.89	3.98	A
	25+25+50+5.0	1.73	1.73	3.47	3.47	---	4.83	10.40	11.01	0.90	2.71	2.93	3.84	A
	25+35+35+3.5	2.00	2.80	2.80	2.80	---	4.27	10.40	10.74	0.84	2.86	3.03	3.64	A
	25+35+35+4.2	1.90	2.66	2.66	3.18	---	4.46	10.40	10.75	0.86	2.86	3.03	3.64	A
	25+35+35+5.0	1.79	2.51	2.51	3.59	---	4.69	10.40	10.88	0.89	2.76	2.98	3.77	A
	25+35+35+6.0	1.67	2.35	2.35	4.03	---	4.97	10.40	11.11	0.90	2.61	2.89	3.98	A
	25+35+42+4.2	1.81	2.53	3.03	3.03	---	4.66	10.40	10.76	0.92	2.86	3.02	3.64	A
	25+35+42+5.0	1.72	2.39	2.87	3.42	---	4.89	10.40	10.89	0.92	2.75	2.98	3.78	A
	25+42+42+4.2	1.73	2.89	2.89	2.89	---	4.86	10.40	10.77	0.95	2.85	3.02	3.65	A
	35+35+35+3.5	2.60	2.60	2.60	2.60	---	4.55	10.40	10.75	0.89	2.86	3.03	3.64	A
	35+35+35+4.2	2.48	2.48	2.48	2.96	---	4.75	10.40	10.76	0.92	2.86	3.02	3.64	A
	35+35+35+5.0	2.35	2.35	2.35	3.35	---	4.97	10.40	10.89	0.95	2.76	2.98	3.77	A
	35+35+42+4.2	2.36	2.36	2.84	2.84	---	4.94	10.40	10.77	0.98	2.85	3.02	3.65	A
	20+20+20+20+2.0	2.08	2.08	2.08	2.08	2.08	3.42	10.40	11.10	0.58	2.62	2.89	3.97	A
	20+20+20+20+2.5	1.98	1.98	1.98	1.98	2.48	3.56	10.40	11.10	0.60	2.62	2.89	3.97	A
	20+20+20+20+3.5	1.81	1.81	1.81	1.81	3.16	3.84	10.40	11.11	0.67	2.61	2.89	3.98	A
	20+20+20+20+4.2	1.70	1.70	1.70	1.70	3.60	4.04	10.40	11.11	0.69	2.61	2.89	3.98	A
	20+20+20+20+5.0	1.60	1.60	1.60	1.60	4.00	4.27	10.40	11.24	0.71	2.51	2.90	4.14	A
	20+20+20+20+6.0	1.49	1.49	1.49	1.49	4.44	4.55	10.40	11.47	0.72	2.38	2.81	4.37	A
	20+20+20+20+7.1	1.38	1.38	1.38	1.38	4.88	4.86	10.40	11.50	0.79	2.36	2.79	4.41	A
	20+20+20+25+2.5	1.90	1.90	1.90	2.35	2.35	3.70	10.40	11.10	0.62	2.62	2.89	3.97	A
	20+20+20+25+3.5	1.73	1.73	1.73	2.17	3.04	3.99	10.40	11.11	0.69	2.61	2.89	3.98	A
	20+20+20+25+4.2	1.64	1.64	1.64	2.05	3.43	4.18	10.40	11.11	0.71	2.61	2.89	3.98	A
	20+20+20+25+5.0	1.54	1.54	1.54	1.93	3.85	4.41	10.40	11.24	0.74	2.51	2.90	4.14	A
	20+20+20+25+6.0	1.43	1.43	1.43	1.80	4.31	4.69	10.40	11.47	0.74	2.38	2.81	4.37	A
	20+20+20+25+7.1	1.33	1.33	1.33	1.67	4.74	5.00	10.40	11.50	0.82	2.36	2.79	4.41	A
	20+20+20+35+3.5	1.90	1.90	1.90	2.35	2.35	3.70	10.40	11.10	0.62	2.62	2.89	3.97	A
	20+20+20+35+4.2	1.52	1.52	1.52	2.66	3.18	4.46	10.40	11.12	0.79	2.55	2.89	4.08	A

HEATING														
OUTDOOR UNIT	INDOOR UNIT	HEATING CAPACITY (kW)					TOTAL CAPACITY (kW)			POWER INPUT HEATING (kW)			COP	ENERGY LABEL
		A ROOM	B ROOM	C ROOM	D ROOM	E ROOM	Min.	Nom.	Max.	Min.	Nom.	Max.		
5MXS90E	20+20+20+35+50	1.43	1.43	1.43	2.51	3.60	4.69	10.40	11.25	0.82	2.51	2.89	4.14	A
	20+20+20+35+60	1.34	1.34	1.34	2.35	4.03	4.97	10.40	11.48	0.82	2.37	2.80	4.39	A
	20+20+20+42+42	1.44	1.44	1.44	3.04	3.04	4.66	10.40	11.13	0.81	2.55	2.88	4.08	A
	20+20+20+42+50	1.37	1.37	1.37	2.87	3.42	4.89	10.40	11.26	0.84	2.56	2.95	4.06	A
	20+20+25+25+25	1.81	1.81	2.26	2.26	2.26	3.84	10.40	11.10	0.67	2.62	2.89	3.97	A
	20+20+25+25+35	1.66	1.66	2.08	2.08	2.92	4.13	10.40	11.11	0.71	2.61	2.89	3.98	A
	20+20+25+25+42	1.58	1.58	1.97	1.97	3.30	4.32	10.40	11.11	0.74	2.56	2.89	4.06	A
	20+20+25+25+50	1.49	1.49	1.86	1.86	3.70	4.55	10.40	11.24	0.76	2.51	2.90	4.14	A
	20+20+25+25+60	1.39	1.39	1.73	1.73	4.16	4.83	10.40	11.47	0.80	2.38	2.81	4.37	A
	20+20+25+35+35	1.54	1.54	1.92	2.70	2.70	4.41	10.40	11.11	0.76	2.61	2.89	3.98	A
	20+20+25+35+42	1.46	1.46	1.84	2.56	3.08	4.61	10.40	11.12	0.82	2.55	2.89	4.08	A
	20+20+25+35+50	1.39	1.39	1.72	2.43	3.47	4.83	10.40	11.25	0.84	2.51	2.89	4.14	A
	20+20+25+42+42	1.40	1.40	1.74	2.93	2.93	4.80	10.40	11.13	0.87	2.60	2.94	4.00	A
	20+20+35+35+35	1.44	1.44	2.52	2.50	2.50	4.69	10.40	11.12	0.84	2.61	2.89	3.98	A
	20+20+35+35+42	1.37	1.37	2.40	2.39	2.87	4.89	10.40	11.13	0.87	2.60	2.94	4.00	A
	20+25+25+25+25	1.72	2.17	2.17	2.17	2.17	3.99	10.40	11.10	0.69	2.62	2.89	3.97	A
	20+25+25+25+35	1.60	2.00	2.00	2.00	2.80	4.27	10.40	11.11	0.74	2.61	2.89	3.98	A
	20+25+25+25+42	1.52	1.90	1.90	1.90	3.18	4.46	10.40	11.11	0.79	2.56	2.89	4.06	A
	20+25+25+25+50	1.44	1.79	1.79	1.79	3.59	4.69	10.40	11.24	0.82	2.51	2.90	4.14	A
	20+25+25+25+60	1.33	1.68	1.68	1.68	4.03	4.97	10.40	11.47	0.82	2.38	2.81	4.37	A
	20+25+25+35+35	1.48	1.86	1.86	2.60	2.60	4.55	10.40	11.11	0.82	2.61	2.89	3.98	A
	20+25+25+35+42	1.41	1.77	1.77	2.48	2.97	4.75	10.40	11.12	0.84	2.55	2.89	4.08	A
	20+25+25+35+50	1.34	1.68	1.68	2.35	3.35	4.97	10.40	11.25	0.87	2.51	2.89	4.14	A
	20+25+25+42+42	1.34	1.69	1.69	2.84	2.84	4.94	10.40	11.13	0.90	2.60	2.94	4.00	A
	20+25+35+35+35	1.38	1.73	2.43	2.43	2.43	4.83	10.40	11.12	0.87	2.61	2.89	3.98	A
	25+25+25+25+25	2.08	2.08	2.08	2.08	2.08	4.13	10.40	11.10	0.72	2.62	2.89	3.97	A
	25+25+25+25+35	1.93	1.93	1.93	1.93	2.68	4.41	10.40	11.11	0.77	2.61	2.89	3.98	A
	25+25+25+25+42	1.83	1.83	1.83	1.83	3.08	4.61	10.40	11.11	0.82	2.56	2.89	4.06	A
	25+25+25+25+50	1.73	1.73	1.73	1.73	3.48	4.83	10.40	11.24	0.85	2.51	2.90	4.14	A
	25+25+25+35+35	1.80	1.80	1.80	2.50	2.50	4.69	10.40	11.11	0.85	2.61	2.89	3.98	A
	25+25+25+35+42	1.71	1.71	1.71	2.40	2.87	4.89	10.40	11.12	0.87	2.61	2.89	3.98	A
	25+25+35+35+35	1.69	1.69	2.34	2.34	2.34	4.97	10.40	11.12	0.90	2.61	2.89	3.98	A